

Hoosick Falls - Rensselaer County PFOA Research
Sampling Results for June 4, 2015. Vickerson and DeMarco

Results in Parts Per Trillion

Location	Sample Description	Source	Result	Water Supply Type
██████ Mickel Hill Road, Brunswick	Summer Kitchen cold tap	well	<2.24ppt	privately owned
██████ Jay Haykes Road, Grafton	Outdoor hose tap	well	<2.24ppt	privately owned
██████ Dunham Reservoir Rd, Grafton	Outdoor Hose tap near back deck	well	<2.24ppt	privately owned
██████ Route 22, Hoosick Falls	Kitchen cold Tap	well	16 ppt	privately owned
██████ Bovie Hill Road, Hoosick Falls	raw tap	Well	194 ppt	privately owned
██████ Route 22, Hoosick Falls	raw tap	Well	<2.24ppt	privately owned
██████ RT 22 Hoosick Falls	workshop sink cold tap	well	14.4 ppt	privately owned
██████ RT 22 Hoosick Falls	Slopsink cold tap	well	58.4 ppt	privately owned
██████ Mountainview Way, Hoosick Falls	Outdoor Hose Tap	well	<2.24ppt	privately owned
██████ Route 67, North Hoosick	Outdoor hose tap	well	<2.24ppt	privately owned
Hoosick Falls High School Route 22	Raw Tap maintenance area	Well	<2.24ppt	ater Supply (not Hoosick Falls Village)
██████ Route 22 Hoosick Falls	Backroom office tap	Village	612 ppt	Public Water Supply
██████ Abbot St, Hoosick Falls	Bathroom Sink Cold tap	Village	618 ppt	Public Water Supply
Village Well #7	Hydrant near well head		620 ppt	Public Water Supply
Village Well #3	Hydrant near well head		151 ppt	Public Water Supply
Village WTP Clearwell	Sample prep sink		662 ppt	Public Water Supply
sample Id #####356-01	Trip Blank	Lab	<2.24ppt	
sample Id #####357-01	Matrix Spike	Lab	246 ppt	
sample Id #####358-01	Trip Blank	Lab	<2.24ppt	
sample Id #####359-01	Matrix Spike	Lab	252 ppt	