

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600021297-SR-1

Page 1 of 1

Report Date: 05/11/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 05/16/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFA

Grab/Collection Date: 05/05/2016 09:10
Date received: 05/05/2016 11:40

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC PRE
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600021297-01

Sample Type: Finished Water

Received Temperature (°C): 13.2

Lab Tracking Id: HFA

Laboratory Special Analysis

Start Date: 05/05/16 12:00 Analysis Date: 05/05/16 15:00

Perfluorooctanoic acid (PFOA): 457 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600021298-SR-1

Page 1 of 1

Report Date: 05/11/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 05/16/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFB

Grab/Collection Date: 05/05/2016 09:12

Date received: 05/05/2016 11:40

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: TEMP GAC MIDWAY

Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600021298-01

Sample Type: Finished Water

Received Temperature (°C): 12.9

Lab Tracking Id: HFB

Laboratory Special Analysis

Start Date: 05/05/16 12:00 Analysis Date: 05/05/16 15:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600021299-SR-1

Page 1 of 1

Report Date: 05/11/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 05/16/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFC

Grab/Collection Date: 05/05/2016 09:15

Date received: 05/05/2016 11:40

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: TEMP GAC POST

Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600021299-01

Sample Type: Finished Water

Received Temperature (°C): 13.4

Lab Tracking Id: HFC

Laboratory Special Analysis

Start Date: 05/05/16 12:00 Analysis Date: 05/05/16 15:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600021300-SR-1

Page 1 of 1

Report Date: 05/11/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 05/16/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFD

Grab/Collection Date: 05/05/2016 09:33

Date received: 05/05/2016 11:40

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: DPW GARAGE RESTROOM CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600021300-01

Sample Type: Finished Water

Received Temperature (°C): 13.4

Lab Tracking Id: HFD

Laboratory Special Analysis

Start Date: 05/05/16 12:00 Analysis Date: 05/05/16 15:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600021301-SR-2

Page 1 of 1

**Replaces information in report No: EHS1600021301-SR-1

Report Date: 05/23/2016

Report retrieved via NYSDOH Health Commerce System by rfs15 on 05/23/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFE

Grab/Collection Date: 05/05/2016 09:44
Date received: 05/05/2016 11:40

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: VILLAGE HALL MENS CWT
24 MAIN STREET
HOOSICK FALLS NY
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600021301-01

Sample Type: Finished Water

Received Temperature (°C): 13.7

Lab Tracking Id: HFE

Laboratory Special Analysis

Start Date: 05/05/16 12:00 Analysis Date: 05/05/16 15:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.