Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600052789-SR-1

Report Date: 12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

PO BOX 509 **EMPIRE STATE PLAZA** ALBANY NY 12201-0509

Submitter's Reference Number: HF4

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Grab/Collection Date: 11/17/2016 08:58 Date received: 11/17/2016 13:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC INFLUENT Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600052789-01

Received Temperature (°C):

Received State:

11.1 Cooling

Lab Tracking Id: HF4

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

11.8 ng/L

Perfluorooctanoic acid (PFOA):

418 ng/L

Perfluorooctanesulfonic acid (PFOS):

NYSELAP NYSELAP

3.97 ng/L

Perfluorononanoic acid (PFNA):

2.34 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NOTES:

Sample temperature upon receipt did not meet method specifications of 10 °C.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937

Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600052787-SR-1

Report Date: 12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER PO BOX 509

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

EMPIRE STATE PLAZA ALBANY NY 12201-0509

Submitter's Reference Number: HF2

Grab/Collection Date: 11/17/2016 08:52 Date received: 11/17/2016 13:45

Wadsworth Center - Environmental Labs

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: TEMPORARY GAC MIDWAY

Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Finished Water

Sample Id: EHS1600052787-01

Received Temperature (°C):

8.4

Lab Tracking Id: HF2

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

3.08 ng/L

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorobexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600052788-SR-1

Report Date: 12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

Page 1 of 1

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509

Submitter's Reference Number: HF3

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON

Collected by:

Grab/Collection Date: 11/17/2016 08:52

Date received: 11/17/2016 13:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC MIDWAY DUPLICATE

Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600052788-01

Received Temperature (°C):

9.6

Lab Tracking Id: HF3

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA): Perfluorooctanesulfonic acid (PFOS): 2.94 ng/L

NYSELAP NYSELAP

<1.91 ng/L

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Page 1 of 1

Report No:

EHS1600052785-SR-1

12/01/2016

Report Date: Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

PO BOX 509

EMPIRE STATE PLAZA ALBANY NY 12201-0509 Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON

Collected by:

Submitter's Reference Number: HF1

Grab/Collection Date: 11/17/2016 08:50 Date received: 11/17/2016 13:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC EFFLUENT WATER PLANT ROAD

Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763 Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Finished Water

Sample Id: EHS1600052785-01

Received Temperature (°C):

12.4

Received State:

Cooling

Lab Tracking Id: HF1

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

NYSELAP

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorobexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NOTES:

[1] Sample temperature upon receipt did not meet method specifications of 10 °C.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600052790-SR-1

Report Date: 12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509 Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Submitter's Reference Number: HF5

Grab/Collection Date: 11/17/2016 09:36 Date received: 11/17/2016 13:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: HOOSICK FALLS DPW GARAGE RESTROOM CWT WATER PLANT RD Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763 Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Finished Water

Sample Id: EHS1600052790-01

Received Temperature (°C):

8.2

Lab Tracking Id: HF5

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No: Report Date: EHS1600052791-SR-1

12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Submitter's Reference Number: HF6

Grab/Collection Date: 11/17/2016 10:01 Date received: 11/17/2016 13:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: HOOSICK FALLS VILLAGE HALL MEN'S CWT 24 MAIN ST Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763 Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Finished Water

Sample Id: EHS1600052791-01

Received Temperature (°C):

12.1

Received State:

Cooling

Lab Tracking Id: HF6

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

Perfluorooctanesulfonic acid (PFOS):

<2.00 ng/L

NYSELAP

<1.91 ng/L

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NOTES:

[1] Sample temperature upon receipt did not meet method specifications of 10 °C.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600052792-SR-1

Page 1 of 1

Report Date: 12/01/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

Wadsworth Center - Environmental Labs

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

County: RENSSELAER Submitted by: T. VICKERSON Collected by:

PO BOX 509

EMPIRE STATE PLAZA ALBANY NY 12201-0509

> Grab/Collection Date: 11/17/2016 Date received: 11/17/2016 13:45

Submitter's Reference Number: FRB

Location/Project/Facility Name: FIELD BLANK Sampling Location Details: PREPARED ON: 11/16/16 - WITH SAMPLE(S): EHS1600052785 - 52791

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Field Blank

Sample Id: EHS1600052792-01

Received Temperature (°C):

10.6

Received State:

Cooling

Lab Tracking Id: FRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 11/18/2016 Analysis Date: 11/18/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

NYSELAP

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration extense. filtration systems.

NOTES:

Sample temperature upon receipt did not meet method specifications of 10 °C.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT