Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054545-SR-1

Report Date: 12/21/2016

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509

Submitter's Reference Number: HF03

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON

Collected by:

Grab/Collection Date: 12/01/2016 09:35

Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC INFLUENT WATER WORKS RD

Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054545-01

Received Temperature (°C):

8.0

Lab Tracking Id: HF03

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

11.0 ng/L

Perfluorooctanoic acid (PFOA):

448 ng/L

Perfluorooctanesulfonic acid (PFOS):

4.38 ng/L

NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937

Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054543-SR-1

Report Date: 12/21/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES

WADSWORTH CENTER PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509

Submitter's Reference Number: HF02

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON

Collected by:

Grab/Collection Date: 12/01/2016 09:45 Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC MIDWAY WATER WORKS RD

Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054543-01

Received Temperature (°C):

6.7

Lab Tracking Id: HF02

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

4.18 ng/L

NYSELAP

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems. filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937

Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054544-SR-1

Report Date: 12/21/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER

PO BOX 509 EMPIRE STATE PLAZA ALBANY NY 12201-0509

Submitter's Reference Number: HF02D

Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Grab/Collection Date: 12/01/2016 09:45 Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC MIDWAY DUPLICATE

Chlorinated: No

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054544-01

Received Temperature (°C):

9.7

Lab Tracking Id: HF02D

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L <2.00 ng/L

Perfluoroheptanoic acid (PFHpA): Perfluorooctanoic acid (PFOA):

3.93 ng/L

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorobexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054542-SR-1

Page 1 of 1

Report Date: 12/21/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

Wadsworth Center - Environmental Labs

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER PO BOX 509 EMPIRE STATE PLAZA County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON

Collected by:

ALBANY NY 12201-0509 Submitter's Reference Number: HF01

Grab/Collection Date: 12/01/2016 09:40

Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: TEMPORARY GAC EFFLUENT WATER WORKS RD Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763 Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054542-01

8.1

Received Temperature (°C):

Lab Tracking Id: HF01

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937

Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054546-SR-1

12/21/2016

Report Date:

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES WADSWORTH CENTER PO BOX 509 EMPIRE STATE PLAZA

ALBANY NY 12201-0509 Submitter's Reference Number: HF04 Wadsworth Center - Environmental Labs

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Grab/Collection Date: 12/01/2016 09:10 Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS Sampling Location Details: DPW GARAGE RESTROOM CWT Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054546-01

Received Temperature (°C):

Lab Tracking Id: HF04

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

8.2

Perfluoroheptanoic acid (PFHpA): Perfluorooctanoic acid (PFOA):

<2.00 ng/L

Perfluorooctanesulfonic acid (PFOS):

<2.00 ng/L <1.91 ng/L NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorobexanesulfonic acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054547-SR-1

Page 1 of 1

Report Date: 12/21/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

REQUESTED BY: DIRECTOR-WCENVIRO

Wadsworth Center - Environmental Labs

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES

WADSWORTH CENTER PO BOX 509

EMPIRE STATE PLAZA ALBANY NY 12201-0509

County: RENSSELAER City (or) Town: HOOSICK FALLS Submitted by: T. VICKERSON Collected by:

Submitter's Reference Number: HF05

Grab/Collection Date: 12/01/2016 09:25

Date received: 12/01/2016 14:45

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: VILLAGE HALL MEN'S CWT

MAIN ST

Chlorinated: Yes

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Id: EHS1600054547-01

Received Temperature (°C):

7.7

Lab Tracking Id: HF05

Sample Type: Finished Water

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

Perfluorooctanesulfonic acid (PFOS):

NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<1.91 ng/L <2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFHxS), perfluorohexanesulfonic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT

Biggs Laboratory PO Box 509 Albany, NY 12201 CLIA# 33D0654341

David Axelrod Institute 120 New Scotland Avenue Albany, NY 12208 CLIA# 33D2005937 Griffin Laboratory 5668 State Farm Road Slingerlands, NY 12159 CLIA# 33D2005935

Report No:

EHS1600054548-SR-1

Report Date: 12/21/2016

Report retrieved via NYSDOH Health Commerce System by Irw03 on 01/03/2017

Page 1 of 1

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE DIVISION OF ENVIRONMENTAL HEALTH SCIENCES

WADSWORTH CENTER PO BOX 509

EMPIRE STATE PLAZA ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER Submitted by: TIM VICKERSON

Collected by:

Submitter's Reference Number: FRB

Grab/Collection Date: 12/01/2016 Date received: 12/01/2016 14:45

Location/Project/Facility Name: FIELD REAGENT BLANK Sampling Location Details: PREPARED ON: 11/30/16 - WITH SAMPLE(S): EHS1600054542 - 54547

FINAL LABORATORY REPORT

Biggs Laboratory NYS ELAP ID: 10763

Laboratory of Organic Analytical Chemistry Lab Director: Dr. K. Kannan Contact: Dr. David Spink 518-486-2530

Sample Type: Field Blank

Sample Id: EHS1600054548-01

Received Temperature (°C):

6.3

Lab Tracking Id: FRB

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS): ISO 25101

Start Date: 12/2/2016 Analysis Date: 12/6/2016

Perfluorobutanesulfonic acid (PFBS):

<1.77 ng/L

Perfluorohexanesulfonic acid (PFHxS):

<1.89 ng/L

Perfluoroheptanoic acid (PFHpA):

<2.00 ng/L

Perfluorooctanoic acid (PFOA):

<2.00 ng/L

Perfluorooctanesulfonic acid (PFOS):

<1.91 ng/L

NYSELAP NYSELAP

Perfluorononanoic acid (PFNA):

<2.00 ng/L

The purpose of our sampling is to analyze for PFOA and/or PFOS, as per ISO 25101:2009 (E) method. This test includes four additional Perfluorinated Chemicals (PFCs): perfluorobutanesulfonic acid (PFBS), perfluorobexanesulfonic acid (acid (PFHxS), perfluoroheptanoic acid (PFHpA), perfluoronoanoic acid (PFNA) that have been validated by the laboratory. These other PFCs may have been detected at very low concentrations-EPA has not established health advisories for these chemicals. All six PFCs are effectively removed from drinking water by granular activated carbon filtration systems.

NYSELAP: Accredited by the New York State Environmental Laboratory Approval Program

END OF REPORT