

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600017194-SR-1**

Report Date: **04/15/2016**

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by lrw03 on 04/15/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: 01

Grab/Collection Date: **04/07/2016 09:10**
Date received: **04/07/2016 12:35**

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC PRE
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600017194-01

Sample Type: Finished Water

Received Temperature (°C): **14.6**

Lab Tracking Id: GAC PRE

Laboratory Special Analysis

Start Date: 04/08/16 08:00 Analysis Date: 04/08/16 13:00

Perfluorooctanoic acid (PFOA): 455 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600017195-SR-1**

Page 1 of 1

Report Date: **04/15/2016**

Report retrieved via NYSDOH Health Commerce System by Irw03 on 04/15/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: 02

Grab/Collection Date: 04/07/2016 09:12
Date received: 04/07/2016 12:35

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC - BETWEEN
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600017195-01

Sample Type: Finished Water

Received Temperature (°C): **15.9**

Lab Tracking Id: GAC BETWEEN

Laboratory Special Analysis

Start Date: 04/08/16 08:00 Analysis Date: 04/08/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600017196-SR-1**

Page 1 of 1

Report Date: **04/15/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 04/15/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: 03

Grab/Collection Date: 04/07/2016 09:15
Date received: 04/07/2016 12:35

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC POST (EFFLUENT)
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600017196-01

Sample Type: Finished Water

Received Temperature (°C): **15.9**

Lab Tracking Id: GAC POST

Laboratory Special Analysis

Start Date: 04/08/16 08:00 Analysis Date: 04/08/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600017198-SR-1**

Page 1 of 1

Report Date: **04/15/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 04/15/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: TIM VICKERSON

Submitter's Reference Number: 05

Grab/Collection Date: 04/07/2016 09:36
Date received: 04/07/2016 12:35

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: DPW GARAGE RESTROOM CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600017198-01

Sample Type: Finished Water

Received Temperature (°C): **15.7**

Lab Tracking Id: DPW GARAGE

Laboratory Special Analysis

Start Date: 04/08/16 08:00 Analysis Date: 04/08/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600017197-SR-1

Page 1 of 1

Report Date: 04/15/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 04/15/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: 04

Grab/Collection Date: 04/07/2016 09:55
Date received: 04/07/2016 12:35

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: VILLAGE HALL MEN'S CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600017197-01

Sample Type: Finished Water

Received Temperature (°C): 14.8

Lab Tracking Id: VILLAGE HALL MENS

Laboratory Special Analysis

Start Date: 04/08/16 08:00 Analysis Date: 04/08/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.