



ANALYSIS REPORT

Prepared by:

Eurofins Lancaster Laboratories Environmental
2425 New Holland Pike
Lancaster, PA 17601

Prepared for:

C. T. Male Associates
50 Century Hill Drive
Latham NY 12110

Report Date: September 17, 2018 15:35

Project: Hoosick Falls WTP

Account #: 37191
Group Number: 1986188
SDG: H0009
PO Number: 14.4756
State of Sample Origin: NY

Electronic Copy To	C. T. Male Associates	Attn: Kirk Moline
Electronic Copy To	C. T. Male Associates	Attn: Dan Reilly
Electronic Copy To	C. T. Male Associates	Attn: Jeff Marx
Electronic Copy To	Barr Engineering Company	Attn: Lauren Brady
Electronic Copy To	Environmental Standards	Attn: St. Gobain
Electronic Copy To	Barr Engineering Company	Attn: Data Mgt

Respectfully Submitted,



Nancy Jean Bornholm
Principal Specialist

(717) 556-7250

To view our laboratory's current scopes of accreditation please go to <http://www.eurofinsus.com/environment-testing/laboratories/eurofins-lancaster-laboratories-environmental/resources/certifications/>. Historical copies may be requested through your project manager.



SAMPLE INFORMATION

<u>Client Sample Description</u>	<u>Sample Collection Date/Time</u>	<u>ELLE#</u>
LTB-180911 Blank Water	09/11/2018	9798079
FTB-180911 Grab Blank Water	09/11/2018 09:55	9798080
PV2-25 Grab Drinking Water	09/11/2018 10:00	9798081
PV2-50 Grab Drinking Water	09/11/2018 10:05	9798082
PV2-75 Grab Drinking Water	09/11/2018 10:10	9798083

The specific methodologies used in obtaining the enclosed analytical results are indicated on the Laboratory Sample Analysis Record.

Project Name: Hoosick Falls WTP
ELLE Group #: 1986188

General Comments:

See the Laboratory Sample Analysis Record section of the Analysis Report for the method references.

All QC met criteria unless otherwise noted in an Analysis Specific Comment below.

Refer to the QC Summary for specific values and acceptance criteria.

Project specific QC samples are not included in this data set.

Matrix QC may not be reported if site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD was performed, unless otherwise specified in the method.

Surrogate recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in an Analysis Specific Comment below.

The samples were received at the appropriate temperature and in accordance with the chain of custody unless otherwise noted.

Analysis Specific Comments:

No additional comments are necessary.

Sample Description: LTB-180911 Blank Water
Hoosick Falls Water Treatment Plant

C. T. Male Associates
ELLE Sample #: WW 9798079
ELLE Group #: 1986188
Matrix: Blank Water

Project Name: Hoosick Falls WTP

Submission Date/Time: 09/12/2018 10:20

Collection Date/Time: 09/11/2018

SDG#: H0009-01TB

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1			ng/l	ng/l	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified			ng/l	ng/l	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.3 U	5.3	1
14473	Perfluorobutanoic acid	375-22-4	5.3 U	5.3	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.6 U	2.6	1
14473	Perfluoropentanoic acid	2706-90-3	5.3 U	5.3	1

Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/14/2018 14:03	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18256010	09/14/2018 00:58	Jason W Knight	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18256014	09/13/2018 09:20	Danielle D McCully	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18256010	09/13/2018 09:10	Danielle D McCully	1

Sample Description: FTB-180911 Grab Blank Water
Hoosick Falls Water Treatment Plant

C. T. Male Associates
ELLE Sample #: WW 9798080
ELLE Group #: 1986188
Matrix: Blank Water

Project Name: Hoosick Falls WTP

Submission Date/Time: 09/12/2018 10:20
Collection Date/Time: 09/11/2018 09:55
SDG#: H0009-02FB

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1			ng/l	ng/l	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified			ng/l	ng/l	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.4 U	5.4	1
14473	Perfluorobutanoic acid	375-22-4	5.4 U	5.4	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.7 U	2.7	1
14473	Perfluoropentanoic acid	2706-90-3	5.4 U	5.4	1

Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/14/2018 14:14	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18256010	09/14/2018 01:07	Jason W Knight	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18256014	09/13/2018 09:20	Danielle D McCully	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18256010	09/13/2018 09:10	Danielle D McCully	1

Sample Description: PV2-25 Grab Drinking Water
Hoosick Falls Water Treatment Plant

C. T. Male Associates
ELLE Sample #: PW 9798081
ELLE Group #: 1986188
Matrix: Drinking Water

Project Name: Hoosick Falls WTP

Submission Date/Time: 09/12/2018 10:20
Collection Date/Time: 09/11/2018 10:00
SDG#: HOO09-03

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1			ng/l	ng/l	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.9 U	1.9	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.9 U	1.9	1
14070	Perfluorobutanesulfonate	375-73-5	1.9 U	1.9	1
14070	Perfluorodecanoic acid	335-76-2	1.9 U	1.9	1
14070	Perfluorododecanoic acid	307-55-1	1.9 U	1.9	1
14070	Perfluoroheptanoic acid	375-85-9	4.0	1.9	1
14070	Perfluorohexanesulfonate	355-46-4	1.9 U	1.9	1
14070	Perfluorohexanoic acid	307-24-4	5.6	1.9	1
14070	Perfluorononanoic acid	375-95-1	1.9 U	1.9	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.9 U	1.9	1
14070	Perfluorooctanoic acid	335-67-1	80	19	10
14070	Perfluorotetradecanoic acid	376-06-7	1.9 U	1.9	1
14070	Perfluorotridecanoic acid	72629-94-8	1.9 U	1.9	1
14070	Perfluoroundecanoic acid	2058-94-8	1.9 U	1.9	1

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified					ng/l		
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1		
14473	8:2 fluorotelomersulfonate	39108-34-4	5.4 U	5.4	1		
14473	Perfluorobutanoic acid	375-22-4	5.5	5.4	1		
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1		
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1		
14473	Perfluorooctanesulfonamide	754-91-6	2.7 U	2.7	1		
14473	Perfluoropentanoic acid	2706-90-3	5.4 U	5.4	1		

Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/14/2018 14:26	Joshua P Trost	1
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/17/2018 12:18	Joshua P Trost	10
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18256010	09/14/2018 01:25	Jason W Knight	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18256014	09/13/2018 09:20	Danielle D McCully	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18256010	09/13/2018 09:10	Danielle D McCully	1

Sample Description: PV2-50 Grab Drinking Water
Hoosick Falls Water Treatment Plant

C. T. Male Associates
ELLE Sample #: PW 9798082
ELLE Group #: 1986188
Matrix: Drinking Water

Project Name: Hoosick Falls WTP

Submission Date/Time: 09/12/2018 10:20
Collection Date/Time: 09/11/2018 10:05
SDG#: H009-04

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1			ng/l	ng/l	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.8 U	1.8	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.8 U	1.8	1
14070	Perfluorobutanesulfonate	375-73-5	1.8 U	1.8	1
14070	Perfluorodecanoic acid	335-76-2	1.8 U	1.8	1
14070	Perfluorododecanoic acid	307-55-1	1.8 U	1.8	1
14070	Perfluoroheptanoic acid	375-85-9	1.8 U	1.8	1
14070	Perfluorohexanesulfonate	355-46-4	1.8 U	1.8	1
14070	Perfluorohexanoic acid	307-24-4	1.8 U	1.8	1
14070	Perfluorononanoic acid	375-95-1	1.8 U	1.8	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.8 U	1.8	1
14070	Perfluorooctanoic acid	335-67-1	1.8 U	1.8	1
14070	Perfluorotetradecanoic acid	376-06-7	1.8 U	1.8	1
14070	Perfluorotridecanoic acid	72629-94-8	1.8 U	1.8	1
14070	Perfluoroundecanoic acid	2058-94-8	1.8 U	1.8	1

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified					ng/l	ng/l	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.9 U	1.9	1		
14473	8:2 fluorotelomersulfonate	39108-34-4	5.6 U	5.6	1		
14473	Perfluorobutanoic acid	375-22-4	7.0	5.6	1		
14473	Perfluorodecanesulfonate	335-77-3	1.9 U	1.9	1		
14473	Perfluoroheptanesulfonate	375-92-8	1.9 U	1.9	1		
14473	Perfluorooctanesulfonamide	754-91-6	2.8 U	2.8	1		
14473	Perfluoropentanoic acid	2706-90-3	5.6 U	5.6	1		

Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/14/2018 14:37	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18256010	09/14/2018 01:34	Jason W Knight	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18256014	09/13/2018 09:20	Danielle D McCully	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18256010	09/13/2018 09:10	Danielle D McCully	1

Sample Description: PV2-75 Grab Drinking Water
Hoosick Falls Water Treatment Plant

C. T. Male Associates
ELLE Sample #: PW 9798083
ELLE Group #: 1986188
Matrix: Drinking Water

Project Name: Hoosick Falls WTP

Submission Date/Time: 09/12/2018 10:20
Collection Date/Time: 09/11/2018 10:10
SDG#: H009-05

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1			ng/l	ng/l	
14070	NEtFOSAA NEtFOSAA is the acronym for N-ethyl perfluorooctanesulfonamidoacetic Acid.	2991-50-6	1.9 U	1.9	1
14070	NMeFOSAA NMeFOSAA is the acronym for N-methyl perfluorooctanesulfonamidoacetic Acid.	2355-31-9	1.9 U	1.9	1
14070	Perfluorobutanesulfonate	375-73-5	1.9 U	1.9	1
14070	Perfluorodecanoic acid	335-76-2	1.9 U	1.9	1
14070	Perfluorododecanoic acid	307-55-1	1.9 U	1.9	1
14070	Perfluoroheptanoic acid	375-85-9	1.9 U	1.9	1
14070	Perfluorohexanesulfonate	355-46-4	1.9 U	1.9	1
14070	Perfluorohexanoic acid	307-24-4	1.9 U	1.9	1
14070	Perfluorononanoic acid	375-95-1	1.9 U	1.9	1
14070	Perfluoro-octanesulfonate	1763-23-1	1.9 U	1.9	1
14070	Perfluorooctanoic acid	335-67-1	1.9 U	1.9	1
14070	Perfluorotetradecanoic acid	376-06-7	1.9 U	1.9	1
14070	Perfluorotridecanoic acid	72629-94-8	1.9 U	1.9	1
14070	Perfluoroundecanoic acid	2058-94-8	1.9 U	1.9	1

CAT No.	Analysis Name	CAS Number	Result	Limit of Quantitation	Dilution Factor
LC/MS/MS Miscellaneous EPA 537 Version 1.1 Modified			ng/l	ng/l	
14473	6:2 fluorotelomersulfonate	27619-97-2	1.8 U	1.8	1
14473	8:2 fluorotelomersulfonate	39108-34-4	5.5 U	5.5	1
14473	Perfluorobutanoic acid	375-22-4	9.4	5.5	1
14473	Perfluorodecanesulfonate	335-77-3	1.8 U	1.8	1
14473	Perfluoroheptanesulfonate	375-92-8	1.8 U	1.8	1
14473	Perfluorooctanesulfonamide	754-91-6	2.8 U	2.8	1
14473	Perfluoropentanoic acid	2706-90-3	5.5 U	5.5	1

Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
14070	14 PFAS Drinking Water List	EPA 537 Version 1.1	1	18256014	09/14/2018 16:44	Joshua P Trost	1
14473	7 PFAS Compounds	EPA 537 Version 1.1 Modified	1	18256010	09/14/2018 01:43	Jason W Knight	1
14381	DW PFAS Prep	EPA 537 Version 1.1	1	18256014	09/13/2018 09:20	Danielle D McCully	1
14091	PFAS Water Prep	EPA 537 Version 1.1 Modified	1	18256010	09/13/2018 09:10	Danielle D McCully	1

Quality Control Summary

Client Name: C. T. Male Associates
Reported: 09/17/2018 15:35

Group Number: 1986188

Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD was performed, unless otherwise specified in the method.

All Inorganic Initial Calibration and Continuing Calibration Blanks met acceptable method criteria unless otherwise noted on the Analysis Report.

Method Blank

Analysis Name	Result	LOQ
	ng/l	ng/l
Batch number: 18256010	Sample number(s): 9798079-9798083	
6:2 fluorotelomersulfonate	2.0 U	2.0
8:2 fluorotelomersulfonate	6.0 U	6.0
Perfluorobutanoic acid	6.0 U	6.0
Perfluorodecanesulfonate	2.0 U	2.0
Perfluoroheptanesulfonate	2.0 U	2.0
Perfluorooctanesulfonamide	3.0 U	3.0
Perfluoropentanoic acid	6.0 U	6.0
Batch number: 18256014	Sample number(s): 9798079-9798083	
NETFOSAA	2.0 U	2.0
NMeFOSAA	2.0 U	2.0
Perfluorobutanesulfonate	2.0 U	2.0
Perfluorodecanoic acid	2.0 U	2.0
Perfluorododecanoic acid	2.0 U	2.0
Perfluoroheptanoic acid	2.0 U	2.0
Perfluorohexanesulfonate	2.0 U	2.0
Perfluorohexanoic acid	2.0 U	2.0
Perfluorononanoic acid	2.0 U	2.0
Perfluoro-octanesulfonate	2.0 U	2.0
Perfluorooctanoic acid	2.0 U	2.0
Perfluorotetradecanoic acid	2.0 U	2.0
Perfluorotridecanoic acid	2.0 U	2.0
Perfluoroundecanoic acid	2.0 U	2.0

LCS/LCSD

Analysis Name	LCS Spike Added	LCS Conc	LCSD Spike Added	LCSD Conc	LCS %REC	LCSD %REC	LCS/LCSD Limits	RPD	RPD Max
	ng/l	ng/l	ng/l	ng/l					
Batch number: 18256010	Sample number(s): 9798079-9798083								
6:2 fluorotelomersulfonate	15.17	17.14	15.17	17.84	113	118	66-155	4	30
8:2 fluorotelomersulfonate	15.33	16.01	15.33	16.7	104	109	66-148	4	30
Perfluorobutanoic acid	5.44	5.99	5.44	6.08	110	112	74-142	2	30
Perfluorodecanesulfonate	5.24	6.33	5.24	6.11	121	117	60-135	3	30
Perfluoroheptanesulfonate	5.18	6.24	5.18	5.72	121	111	64-135	9	30
Perfluorooctanesulfonamide	5.44	5.77	5.44	5.32	106	98	65-164	8	30

*- Outside of specification

(1) The result for one or both determinations was less than five times the LOQ.

(2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

Quality Control Summary

Client Name: C. T. Male Associates
Reported: 09/17/2018 15:35

Group Number: 1986188

LCS/LCSD (continued)

Analysis Name	LCS Spike Added ng/l	LCS Conc ng/l	LCSD Spike Added ng/l	LCSD Conc ng/l	LCS %REC	LCSD %REC	LCS/LCSD Limits	RPD	RPD Max
Perfluoropentanoic acid	5.44	5.96	5.44	6.21	110	114	74-134	4	30
Batch number: 18256014	Sample number(s): 9798079-9798083								
NEtFOSAA	20	16.51	20	17.42	83	87	70-130	5	30
NMeFOSAA	20	17.26	20	17.52	86	88	70-130	1	30
Perfluorobutanesulfonate	18.12	16.15	18.12	16.68	89	92	70-130	3	30
Perfluorodecanoic acid	20.48	21.29	20.48	19.79	104	97	70-130	7	30
Perfluorododecanoic acid	20.48	18.15	20.48	18.6	89	91	70-130	2	30
Perfluoroheptanoic acid	20.48	19.76	20.48	20.04	96	98	70-130	1	30
Perfluorohexanesulfonate	19.36	17.46	19.36	17.29	90	89	70-130	1	30
Perfluorohexanoic acid	20.48	18.89	20.48	19.01	92	93	70-130	1	30
Perfluorononanoic acid	20.48	19.78	20.48	19.81	97	97	70-130	0	30
Perfluoro-octanesulfonate	19.58	17.35	19.58	17.02	89	87	70-130	2	30
Perfluorooctanoic acid	20.48	17.5	20.48	17.32	85	85	70-130	1	30
Perfluorotetradecanoic acid	20.48	15.42	20.48	17.19	75	84	70-130	11	30
Perfluorotridecanoic acid	20.48	16.17	20.48	17.51	79	85	70-130	8	30
Perfluoroundecanoic acid	20.48	20.76	20.48	19.81	101	97	70-130	5	30

Labeled Isotope Quality Control

Labeled isotope recoveries which are outside of the QC window are confirmed unless otherwise noted on the analysis report.

Analysis Name: 7 PFAS Compounds
Batch number: 18256010

	13C4-PFBA	13C5-PFPeA	13C3-PFHxS	13C2-6:2-FTS	13C8-PFOS	13C2-8:2-FTS
9798079	85	86	81	109	87	103
9798080	100	105	91	120	102	118
9798081	85	90	81	102	86	103
9798082	90	96	92	118	92	106
9798083	89	97	86	113	85	102
Blank	90	91	84	113	86	114
LCS	97	100	85	122	101	111
LCSD	92	95	89	119	89	110
Limits:	33-123	31-157	34-126	32-170	50-121	27-164

13C8-PFOSA

9798079	83
9798080	97
9798081	77
9798082	93

*- Outside of specification

- (1) The result for one or both determinations was less than five times the LOQ.
- (2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

Quality Control Summary

Client Name: C. T. Male Associates
Reported: 09/17/2018 15:35

Group Number: 1986188

Labeled Isotope Quality Control (continued)

Labeled isotope recoveries which are outside of the QC window are confirmed unless otherwise noted on the analysis report.

Analysis Name: 7 PFAS Compounds

Batch number: 18256010

13C8-PFOSA

9798083	90
Blank	86
LCS	89
LCSD	94

Limits: 11-127

Analysis Name: 14 PFAS Drinking Water List

Batch number: 18256014

13C2-PFHxA

13C2-PFDA

D5-NetFOSAA

9798079	80	96	89
9798080	72	91	78
9798081	83	93	85
9798082	85	96	84
9798083	71	91	82
Blank	91	105	95
LCS	85	101	91
LCSD	83	93	86

Limits: 70-130 70-130 70-130

*- Outside of specification

(1) The result for one or both determinations was less than five times the LOQ.

(2) The unspiked result was more than four times the spike added.

P##### is indicative of a Background or Unspiked sample that is batch matrix QC and was not performed using a sample from this submission group.

Environmental Analysis Request/Chain of Custody



Lancaster Laboratories
Environmental

For Eurofins Lancaster Laboratories Environmental use only

Acct. # 37191 Group # 1986188 Sample # 9798079-83

COC # 551696

Client Information				Matrix				Analysis Requested										For Lab Use Only						
Client: <u>CT Male Associates</u>		Acct. #:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Total # of Containers	Preservation and Filtration Codes										FSC: _____	Remarks					
Project Name#: <u>Hoosick Falls WTP</u>		PWSID #:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		7 PFCs (EPA 537 mod.)	14 PFCs (EPA 537 ver. 1.1) N											SCR#: _____				
Project Manager: <u>Kick Moline</u>		P.O. #: <u>14.4756</u>		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Other: <u>Reverse Water</u>													Preservation Codes H=HCl Z=Trizma T=Thiosulfate N=HNO ₃ B=NaOH S=H ₂ SO ₄ P=H ₃ PO ₄ F=Field Filtered O=Other				
Sampler: <u>Cliff Bondi</u>		Quote #:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		Soil <input type="checkbox"/>	Water <input type="checkbox"/>	NPDES <input type="checkbox"/>	Surface <input type="checkbox"/>	Ground <input type="checkbox"/>	Tissue <input type="checkbox"/>											Remarks
State where samples were collected: <u>NY</u>		For Compliance: Yes <input type="checkbox"/> No <input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Grab							Composite										
Sample Identification		Collected		Grab	Composite	Soil		Water	Other	Total # of Containers														
Date	Time																							
<u>LTB-180911</u>	<u>9/11/18</u>		<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>	<u>4</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>									<u>2 Trizma / 2 Non-Trizma</u>				
<u>FTB-180911</u>		<u>0955</u>	<input checked="" type="checkbox"/>					<input checked="" type="checkbox"/>	<u>4</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>													
<u>PV2-25</u>		<u>1000</u>	<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		<u>4</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>													
<u>PV2-50</u>		<u>1005</u>	<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		<u>4</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>													
<u>PV2-75</u>		<u>1010</u>	<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>		<u>4</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>													

Turnaround Time (TAT) Requested (please circle) (Standard) <input checked="" type="radio"/> Rush <input type="radio"/> (Rush TAT is subject to laboratory approval and surcharge.) Date results are needed: <u>10 Days</u> E-mail address: <u>K.moline@ctmale.com</u>	Relinquished by <u>Cliff Bondi</u>	Date <u>9/11/18</u>	Time <u>1730</u>	Received by	Date	Time
	Relinquished by	Date	Time	Received by	Date	Time
	Relinquished by	Date	Time	Received by	Date	Time
	Relinquished by	Date	Time	Received by	Date	Time
	Relinquished by	Date	Time	Received by	Date	Time
Data Package Options (circle if required) Type I (EPA Level 3 Equivalent/non-CLP) Type III (Reduced non-CLP) NYSDEC Category A or <input checked="" type="radio"/> B Type VI (Raw Data Only) NJ DKQP TX TRRP-13 MA MCP CT RCP	Relinquished by	Date	Time	Received by <u>MWR</u>	Date <u>9/12/18</u>	Time <u>1020</u>
EDD Required? Yes No If yes, format: _____	Relinquished by Commercial Carrier: UPS _____ FedEx <input checked="" type="checkbox"/> Other _____			Temperature upon receipt <u>1.7</u> °C		
Site-Specific QC (MS/MSD/Dup)? Yes No (If yes, indicate QC sample and submit triplicate sample volume.)						



Client: C.T. Male Associates

Hoosick Falls WTP

Delivery and Receipt Information

Delivery Method:	<u>Fed Ex</u>	Arrival Timestamp:	<u>09/12/2018 10:20</u>
Number of Packages:	<u>1</u>	Number of Projects:	<u>1</u>
State/Province of Origin:	<u>NY</u>		

Arrival Condition Summary

Shipping Container Sealed:	Yes	Sample IDs on COC match Containers:	Yes
Custody Seal Present:	Yes	Sample Date/Times match COC:	Yes
Custody Seal Intact:	Yes	VOA Vial Headspace \geq 6mm:	N/A
Samples Chilled:	Yes	Total Trip Blank Qty:	4
Paperwork Enclosed:	Yes	Trip Blank Type:	See Below
Samples Intact:	Yes	Air Quality Samples Present:	No
Missing Samples:	No		
Extra Samples:	No		
Discrepancy in Container Qty on COC:	No		

Trip Blank Type(s): Unpreserved

Unpacked by Nicole Reiff (25684) at 16:36 on 09/12/2018

Samples Chilled Details: Hoosick Falls WTP

Thermometer Types: DT = Digital (Temp. Bottle) IR = Infrared (Surface Temp) All Temperatures in °C.

<u>Cooler #</u>	<u>Thermometer ID</u>	<u>Corrected Temp</u>	<u>Therm. Type</u>	<u>Ice Type</u>	<u>Ice Present?</u>	<u>Ice Container</u>	<u>Elevated Temp?</u>
1	DT146	1.7	DT	Wet	Y	Bagged	N

Explanation of Symbols and Abbreviations

The following defines common symbols and abbreviations used in reporting technical data:

BMQL	Below Minimum Quantitation Level	mL	milliliter(s)
C	degrees Celsius	MPN	Most Probable Number
cfu	colony forming units	N.D.	non-detect
CP Units	cobalt-chloroplatinate units	ng	nanogram(s)
F	degrees Fahrenheit	NTU	nephelometric turbidity units
g	gram(s)	pg/L	picogram/liter
IU	International Units	RL	Reporting Limit
kg	kilogram(s)	TNTC	Too Numerous To Count
L	liter(s)	µg	microgram(s)
lb.	pound(s)	µL	microliter(s)
m3	cubic meter(s)	umhos/cm	micromhos/cm
meq	milliequivalents	MCL	Maximum Contamination Limit
mg	milligram(s)		
<	less than		
>	greater than		
ppm	parts per million - One ppm is equivalent to one milligram per kilogram (mg/kg) or one gram per million grams. For aqueous liquids, ppm is usually taken to be equivalent to milligrams per liter (mg/l), because one liter of water has a weight very close to a kilogram. For gases or vapors, one ppm is equivalent to one microliter per liter of gas.		
ppb	parts per billion		
Dry weight basis	Results printed under this heading have been adjusted for moisture content. This increases the analyte weight concentration to approximate the value present in a similar sample without moisture. All other results are reported on an as-received basis.		

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Measurement uncertainty values, as applicable, are available upon request.

Tests results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" are not performed within 15 minutes.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. THE FOREGOING EXPRESS WARRANTY IS EXCLUSIVE AND IS GIVEN IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED. WE DISCLAIM ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING A WARRANTY OF FITNESS FOR PARTICULAR PURPOSE AND WARRANTY OF MERCHANTABILITY. IN NO EVENT SHALL EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL, LLC BE LIABLE FOR INDIRECT, SPECIAL, CONSEQUENTIAL, OR INCIDENTAL DAMAGES INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF PROFIT OR GOODWILL REGARDLESS OF (A) THE NEGLIGENCE (EITHER SOLE OR CONCURRENT) OF EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL AND (B) WHETHER EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL HAS BEEN INFORMED OF THE POSSIBILITY OF SUCH DAMAGES. We accept no legal responsibility for the purposes for which the client uses the test results. No purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

Data Qualifiers

Qualifier	Definition
C	Result confirmed by reanalysis
D1	Indicates for dual column analyses that the result is reported from column 1
D2	Indicates for dual column analyses that the result is reported from column 2
E	Concentration exceeds the calibration range
K1	Initial Calibration Blank is above the QC limit and the sample result is ND
K2	Continuing Calibration Blank is above the QC limit and the sample result is ND
K3	Initial Calibration Verification is above the QC limit and the sample result is ND
K4	Continuing Calibration Verification is above the QC limit and the sample result is ND
J (or G, I, X)	Estimated value \geq the Method Detection Limit (MDL or DL) and $<$ the Limit of Quantitation (LOQ or RL)
P	Concentration difference between the primary and confirmation column $>40\%$. The lower result is reported.
P^	Concentration difference between the primary and confirmation column $> 40\%$. The higher result is reported.
U	Analyte was not detected at the value indicated
V	Concentration difference between the primary and confirmation column $>100\%$. The reporting limit is raised due to this disparity and evident interference.
W	The dissolved oxygen uptake for the unseeded blank is greater than 0.20 mg/L.
Z	Laboratory Defined - see analysis report

Additional Organic and Inorganic CLP qualifiers may be used with Form 1 reports as defined by the CLP methods. Qualifiers specific to Dioxin/Furans and PCB Congeners are detailed on the individual Analysis Report.