

ANALYTICAL REPORT

PREPARED FOR

Attn: Jonathan Dippert
CT Male Associates DPC
50 Century Hill Dr
Latham, New York 12110

Generated 6/21/2024 5:15:24 PM

JOB DESCRIPTION

Hoosick Falls WTP
HOO

JOB NUMBER

410-175063-1

Eurofins Lancaster Laboratories Environment Testing, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
6/21/2024 5:15:24 PM

Authorized for release by
Kelly Gallagher, Project Manager
kelly.gallagher@et.eurofinsus.com
(717)205-7820

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
 - Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
 - Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.
- Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.



Table of Contents

Cover Page	1
Table of Contents	4
Definitions/Glossary	5
Case Narrative	6
Detection Summary	7
Client Sample Results	8
Surrogate Summary	14
Isotope Dilution Summary	15
QC Sample Results	16
QC Association Summary	18
Lab Chronicle	19
Certification Summary	21
Method Summary	22
Sample Summary	23
Chain of Custody	24
Receipt Checklists	25



Definitions/Glossary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Qualifiers

LCMS

Qualifier	Qualifier Description
*5+	Isotope dilution analyte is outside acceptance limits, high biased.
cn	Refer to Case Narrative for further detail
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: CT Male Associates DPC
Project: Hoosick Falls WTP

Job ID: 410-175063-1

Job ID: 410-175063-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-175063-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 6/7/2024 9:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.6°C.

PFAS

Method PFC_IDA: The recovery for the labeled isotope(s) M2-6:2 FTS in the method blank/laboratory control spike samples associated with the following samples: GAC INFLUENT (410-175063-1), GAC MIDFLUENT (410-175063-2), GAC EFFLUENT (410-175063-3), PV-2_75 (410-175063-4), SG1-FTB01-240606 (410-175063-5) and SG1-LTB01-240606 (410-175063-6) is outside the QC acceptance limits. Since the recovery for target analytes is within the limits, the data is reported.

Method PFC_IDA: The recovery for the labeled isotope: M2-6:2 FTS in the following samples: GAC INFLUENT (410-175063-1), GAC MIDFLUENT (410-175063-2), GAC EFFLUENT (410-175063-3), PV-2_75 (410-175063-4), SG1-FTB01-240606 (410-175063-5) and SG1-LTB01-240606 (410-175063-6) is outside the QC acceptance limits. Since the recovery is high and the native analyte is not detected in the sample, the data is reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-175063-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	3.5		1.8	ng/L	1		537 (Mod)	Total/NA
Perfluorooctanesulfonamide	6.8		1.8	ng/L	1		537 (Mod)	Total/NA
Perfluoropentanoic acid	2.7		1.8	ng/L	1		537 (Mod)	Total/NA
Perfluoroheptanoic acid	9.2		1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorohexanoic acid	9.4		1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanesulfonic acid	3.2		1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanoic acid - DL	380		17	ng/L	10		EPA 537.1	Total/NA

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-175063-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	3.5		1.7	ng/L	1		537 (Mod)	Total/NA

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-175063-3

No Detections.

Client Sample ID: PV-2_75

Lab Sample ID: 410-175063-4

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	6.5		1.7	ng/L	1		537 (Mod)	Total/NA

Client Sample ID: SG1-FTB01-240606

Lab Sample ID: 410-175063-5

No Detections.

Client Sample ID: SG1-LTB01-240606

Lab Sample ID: 410-175063-6

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-175063-1

Date Collected: 06/06/24 09:45

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
Perfluorobutanoic acid	3.5		1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
Perfluorooctanesulfonamide	6.8		1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1
Perfluoropentanoic acid	2.7		1.8	ng/L		06/16/24 14:07	06/20/24 16:34	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	338	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 16:34	1
M2-8:2 FTS	103		37 - 200	06/16/24 14:07	06/20/24 16:34	1
13C4 PFBA	95		22 - 174	06/16/24 14:07	06/20/24 16:34	1
13C5 PFPeA	104		33 - 196	06/16/24 14:07	06/20/24 16:34	1
13C8 PFOS	100		59 - 155	06/16/24 14:07	06/20/24 16:34	1
13C8 FOSA	83		10 - 155	06/16/24 14:07	06/20/24 16:34	1
13C3 PFHxS	92		48 - 169	06/16/24 14:07	06/20/24 16:34	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
NMeFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluoroheptanoic acid	9.2		1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorohexanoic acid	9.4		1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorooctanesulfonic acid	3.2		1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:16	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	115		70 - 130	06/10/24 15:15	06/14/24 07:16	1
13C2 PFHxA	119		70 - 130	06/10/24 15:15	06/14/24 07:16	1
d5-NEtFOSAA	96		70 - 130	06/10/24 15:15	06/14/24 07:16	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 - DL

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanoic acid	380		17	ng/L		06/10/24 15:15	06/15/24 18:03	10

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	102		70 - 130	06/10/24 15:15	06/15/24 18:03	10
13C2 PFHxA	104		70 - 130	06/10/24 15:15	06/15/24 18:03	10
d5-NEtFOSAA	105		70 - 130	06/10/24 15:15	06/15/24 18:03	10

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-175063-2

Date Collected: 06/06/24 09:48

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
Perfluorobutanoic acid	3.5		1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 16:48	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	405	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 16:48	1
M2-8:2 FTS	109		37 - 200	06/16/24 14:07	06/20/24 16:48	1
13C4 PFBA	95		22 - 174	06/16/24 14:07	06/20/24 16:48	1
13C5 PFPeA	89		33 - 196	06/16/24 14:07	06/20/24 16:48	1
13C8 PFOS	106		59 - 155	06/16/24 14:07	06/20/24 16:48	1
13C8 FOSA	97		10 - 155	06/16/24 14:07	06/20/24 16:48	1
13C3 PFHxS	92		48 - 169	06/16/24 14:07	06/20/24 16:48	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
NMeFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	93		70 - 130	06/10/24 15:15	06/14/24 07:27	1
13C2 PFHxA	104		70 - 130	06/10/24 15:15	06/14/24 07:27	1
d5-NEtFOSAA	93		70 - 130	06/10/24 15:15	06/14/24 07:27	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-175063-3

Date Collected: 06/06/24 09:50

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:02	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	457	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 17:02	1
M2-8:2 FTS	122		37 - 200	06/16/24 14:07	06/20/24 17:02	1
13C4 PFBA	85		22 - 174	06/16/24 14:07	06/20/24 17:02	1
13C5 PFPeA	81		33 - 196	06/16/24 14:07	06/20/24 17:02	1
13C8 PFOS	104		59 - 155	06/16/24 14:07	06/20/24 17:02	1
13C8 FOSA	96		10 - 155	06/16/24 14:07	06/20/24 17:02	1
13C3 PFHxS	90		48 - 169	06/16/24 14:07	06/20/24 17:02	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
NMeFOSAA	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorobutanesulfonic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorodecanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorododecanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluoroheptanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorohexanesulfonic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorohexanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorononanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorooctanesulfonic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorooctanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorotetradecanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluorotridecanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1
Perfluoroundecanoic acid	1.6	U	1.6	ng/L		06/10/24 15:15	06/14/24 07:39	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	95		70 - 130	06/10/24 15:15	06/14/24 07:39	1
13C2 PFHxA	100		70 - 130	06/10/24 15:15	06/14/24 07:39	1
d5-NEtFOSAA	92		70 - 130	06/10/24 15:15	06/14/24 07:39	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: PV-2_75

Lab Sample ID: 410-175063-4

Date Collected: 06/06/24 09:55

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
Perfluorobutanoic acid	6.5		1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		06/16/24 14:07	06/20/24 17:15	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	417	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 17:15	1
M2-8:2 FTS	119		37 - 200	06/16/24 14:07	06/20/24 17:15	1
13C4 PFBA	97		22 - 174	06/16/24 14:07	06/20/24 17:15	1
13C5 PFPeA	93		33 - 196	06/16/24 14:07	06/20/24 17:15	1
13C8 PFOS	100		59 - 155	06/16/24 14:07	06/20/24 17:15	1
13C8 FOSA	104		10 - 155	06/16/24 14:07	06/20/24 17:15	1
13C3 PFHxS	90		48 - 169	06/16/24 14:07	06/20/24 17:15	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
NMeFOSAA	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		06/10/24 15:15	06/14/24 07:51	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	92		70 - 130	06/10/24 15:15	06/14/24 07:51	1
13C2 PFHxA	101		70 - 130	06/10/24 15:15	06/14/24 07:51	1
d5-NEtFOSAA	93		70 - 130	06/10/24 15:15	06/14/24 07:51	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: SG1-FTB01-240606

Lab Sample ID: 410-175063-5

Date Collected: 06/06/24 10:00

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:29	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	409	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 17:29	1
M2-8:2 FTS	132		37 - 200	06/16/24 14:07	06/20/24 17:29	1
13C4 PFBA	81		22 - 174	06/16/24 14:07	06/20/24 17:29	1
13C5 PFPeA	100		33 - 196	06/16/24 14:07	06/20/24 17:29	1
13C8 PFOS	107		59 - 155	06/16/24 14:07	06/20/24 17:29	1
13C8 FOSA	102		10 - 155	06/16/24 14:07	06/20/24 17:29	1
13C3 PFHxS	93		48 - 169	06/16/24 14:07	06/20/24 17:29	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
NMeFOSAA	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorobutanesulfonic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorodecanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorododecanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluoroheptanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorohexanesulfonic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorohexanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorononanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorooctanesulfonic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorooctanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorotetradecanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluorotridecanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1
Perfluoroundecanoic acid	1.9	U	1.9	ng/L		06/10/24 15:15	06/14/24 08:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	94		70 - 130	06/10/24 15:15	06/14/24 08:02	1
13C2 PFHxA	98		70 - 130	06/10/24 15:15	06/14/24 08:02	1
d5-NEtFOSAA	95		70 - 130	06/10/24 15:15	06/14/24 08:02	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: SG1-LTB01-240606

Lab Sample ID: 410-175063-6

Date Collected: 06/06/24 00:00

Matrix: Water

Date Received: 06/07/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		06/16/24 14:07	06/20/24 17:42	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	392	*5+ cn	40 - 200	06/16/24 14:07	06/20/24 17:42	1
M2-8:2 FTS	120		37 - 200	06/16/24 14:07	06/20/24 17:42	1
13C4 PFBA	82		22 - 174	06/16/24 14:07	06/20/24 17:42	1
13C5 PFPeA	94		33 - 196	06/16/24 14:07	06/20/24 17:42	1
13C8 PFOS	103		59 - 155	06/16/24 14:07	06/20/24 17:42	1
13C8 FOSA	97		10 - 155	06/16/24 14:07	06/20/24 17:42	1
13C3 PFHxS	88		48 - 169	06/16/24 14:07	06/20/24 17:42	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
NMeFOSAA	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 08:14	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	94		70 - 130	06/10/24 15:15	06/14/24 08:14	1
13C2 PFHxA	98		70 - 130	06/10/24 15:15	06/14/24 08:14	1
d5-NEtFOSAA	91		70 - 130	06/10/24 15:15	06/14/24 08:14	1

Surrogate Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		PFDA (70-130)	PFHxA (70-130)	d5NEFOS (70-130)
410-175063-1	GAC INFLUENT	115	119	96
410-175063-1 - DL	GAC INFLUENT	102	104	105
410-175063-2	GAC MIDFLUENT	93	104	93
410-175063-3	GAC EFFLUENT	95	100	92
410-175063-4	PV-2_75	92	101	93
410-175063-5	SG1-FTB01-240606	94	98	95
410-175063-6	SG1-LTB01-240606	94	98	91
LCS 410-515657/2-A	Lab Control Sample	89	93	97
MB 410-515657/1-A	Method Blank	87	87	91

Surrogate Legend

PFDA = 13C2 PFDA

PFHxA = 13C2 PFHxA

d5NEFOS = d5-NEtFOSAA

Isotope Dilution Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)						
		M262FTS (40-200)	M282FTS (37-200)	PFBA (22-174)	PFPeA (33-196)	C8PFOS (59-155)	PFOSA (10-155)	C3PFHS (48-169)
410-175063-1	GAC INFLUENT	338 *5+ cn	103	95	104	100	83	92
410-175063-2	GAC MIDFLUENT	405 *5+ cn	109	95	89	106	97	92
410-175063-3	GAC EFFLUENT	457 *5+ cn	122	85	81	104	96	90
410-175063-4	PV-2_75	417 *5+ cn	119	97	93	100	104	90
410-175063-5	SG1-FTB01-240606	409 *5+ cn	132	81	100	107	102	93
410-175063-6	SG1-LTB01-240606	392 *5+ cn	120	82	94	103	97	88
LCS 410-517788/2-A	Lab Control Sample	451 *5+	125	95	101	108	102	93
MB 410-517788/1-A	Method Blank	381 *5+	122	87	92	101	99	96
Surrogate Legend								
M262FTS = M2-6:2 FTS								
M282FTS = M2-8:2 FTS								
PFBA = 13C4 PFBA								
PFPeA = 13C5 PFPeA								
C8PFOS = 13C8 PFOS								
PFOSA = 13C8 FOSA								
C3PFHS = 13C3 PFHxS								

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Lab Sample ID: MB 410-517788/1-A

Matrix: Water

Analysis Batch: 519504

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 517788

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		06/16/24 14:07	06/20/24 13:38	1

Isotope Dilution	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	381	*5+	40 - 200	06/16/24 14:07	06/20/24 13:38	1
M2-8:2 FTS	122		37 - 200	06/16/24 14:07	06/20/24 13:38	1
13C4 PFBA	87		22 - 174	06/16/24 14:07	06/20/24 13:38	1
13C5 PFPeA	92		33 - 196	06/16/24 14:07	06/20/24 13:38	1
13C8 PFOS	101		59 - 155	06/16/24 14:07	06/20/24 13:38	1
13C8 FOSA	99		10 - 155	06/16/24 14:07	06/20/24 13:38	1
13C3 PFHxS	96		48 - 169	06/16/24 14:07	06/20/24 13:38	1

Lab Sample ID: LCS 410-517788/2-A

Matrix: Water

Analysis Batch: 519504

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 517788

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
6:2 Fluorotelomer sulfonic acid	24.3	24.9		ng/L		103	61 - 132
8:2 Fluorotelomer sulfonic acid	24.5	23.2		ng/L		94	55 - 134
Perfluorobutanoic acid	25.6	25.5		ng/L		99	58 - 130
Perfluorodecanesulfonic acid	24.7	20.2		ng/L		82	55 - 130
Perfluoroheptanesulfonic acid	24.4	25.6		ng/L		105	59 - 130
Perfluorooctanesulfonamide	25.6	27.3		ng/L		107	67 - 132
Perfluoropentanoic acid	25.6	25.9		ng/L		101	60 - 130

Isotope Dilution	LCS %Recovery	LCS Qualifier	Limits
M2-6:2 FTS	451	*5+	40 - 200
M2-8:2 FTS	125		37 - 200
13C4 PFBA	95		22 - 174
13C5 PFPeA	101		33 - 196
13C8 PFOS	108		59 - 155
13C8 FOSA	102		10 - 155
13C3 PFHxS	93		48 - 169

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Lab Sample ID: MB 410-515657/1-A

Matrix: Water

Analysis Batch: 517036

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 515657

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
NMeFOSAA	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: MB 410-515657/1-A

Matrix: Water

Analysis Batch: 517036

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 515657

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorodecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		06/10/24 15:15	06/14/24 03:59	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	87		70 - 130	06/10/24 15:15	06/14/24 03:59	1
13C2 PFHxA	87		70 - 130	06/10/24 15:15	06/14/24 03:59	1
d5-NEtFOSAA	91		70 - 130	06/10/24 15:15	06/14/24 03:59	1

Lab Sample ID: LCS 410-515657/2-A

Matrix: Water

Analysis Batch: 517036

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 515657

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
NEtFOSAA	20.5	17.0		ng/L		83	70 - 130
NMeFOSAA	20.5	17.5		ng/L		85	70 - 130
Perfluorobutanesulfonic acid	18.1	14.0		ng/L		77	70 - 130
Perfluorodecanoic acid	20.5	17.4		ng/L		85	70 - 130
Perfluorododecanoic acid	20.5	16.5		ng/L		81	70 - 130
Perfluoroheptanoic acid	20.5	17.7		ng/L		86	70 - 130
Perfluorohexanesulfonic acid	18.7	16.7		ng/L		90	70 - 130
Perfluorohexanoic acid	20.5	17.5		ng/L		85	70 - 130
Perfluorononanoic acid	20.5	18.1		ng/L		88	70 - 130
Perfluorooctanesulfonic acid	19.0	16.3		ng/L		86	70 - 130
Perfluorooctanoic acid	20.5	17.8		ng/L		87	70 - 130
Perfluorotetradecanoic acid	20.5	16.9		ng/L		82	70 - 130
Perfluorotridecanoic acid	20.5	16.9		ng/L		82	70 - 130
Perfluoroundecanoic acid	20.5	16.7		ng/L		81	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
13C2 PFDA	89		70 - 130
13C2 PFHxA	93		70 - 130
d5-NEtFOSAA	97		70 - 130

QC Association Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

LCMS

Prep Batch: 515657

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-175063-1	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-175063-1 - DL	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-175063-2	GAC MIDFLUENT	Total/NA	Water	537.1 DW Prep	
410-175063-3	GAC EFFLUENT	Total/NA	Water	537.1 DW Prep	
410-175063-4	PV-2_75	Total/NA	Water	537.1 DW Prep	
410-175063-5	SG1-FTB01-240606	Total/NA	Water	537.1 DW Prep	
410-175063-6	SG1-LTB01-240606	Total/NA	Water	537.1 DW Prep	
MB 410-515657/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-515657/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	

Analysis Batch: 517036

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-175063-1	GAC INFLUENT	Total/NA	Water	EPA 537.1	515657
410-175063-2	GAC MIDFLUENT	Total/NA	Water	EPA 537.1	515657
410-175063-3	GAC EFFLUENT	Total/NA	Water	EPA 537.1	515657
410-175063-4	PV-2_75	Total/NA	Water	EPA 537.1	515657
410-175063-5	SG1-FTB01-240606	Total/NA	Water	EPA 537.1	515657
410-175063-6	SG1-LTB01-240606	Total/NA	Water	EPA 537.1	515657
MB 410-515657/1-A	Method Blank	Total/NA	Water	EPA 537.1	515657
LCS 410-515657/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	515657

Analysis Batch: 517750

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-175063-1 - DL	GAC INFLUENT	Total/NA	Water	EPA 537.1	515657

Prep Batch: 517788

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-175063-1	GAC INFLUENT	Total/NA	Water	SPE	
410-175063-2	GAC MIDFLUENT	Total/NA	Water	SPE	
410-175063-3	GAC EFFLUENT	Total/NA	Water	SPE	
410-175063-4	PV-2_75	Total/NA	Water	SPE	
410-175063-5	SG1-FTB01-240606	Total/NA	Water	SPE	
410-175063-6	SG1-LTB01-240606	Total/NA	Water	SPE	
MB 410-517788/1-A	Method Blank	Total/NA	Water	SPE	
LCS 410-517788/2-A	Lab Control Sample	Total/NA	Water	SPE	

Analysis Batch: 519504

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-175063-1	GAC INFLUENT	Total/NA	Water	537 (Mod)	517788
410-175063-2	GAC MIDFLUENT	Total/NA	Water	537 (Mod)	517788
410-175063-3	GAC EFFLUENT	Total/NA	Water	537 (Mod)	517788
410-175063-4	PV-2_75	Total/NA	Water	537 (Mod)	517788
410-175063-5	SG1-FTB01-240606	Total/NA	Water	537 (Mod)	517788
410-175063-6	SG1-LTB01-240606	Total/NA	Water	537 (Mod)	517788
MB 410-517788/1-A	Method Blank	Total/NA	Water	537 (Mod)	517788
LCS 410-517788/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	517788

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-175063-1

Date Collected: 06/06/24 09:45

Matrix: Water

Date Received: 06/07/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 16:34
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 07:16
Total/NA	Prep	537.1 DW Prep	DL		515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1	DL	10	517750	QD9Y	ELLE	06/15/24 18:03

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-175063-2

Date Collected: 06/06/24 09:48

Matrix: Water

Date Received: 06/07/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 16:48
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 07:27

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-175063-3

Date Collected: 06/06/24 09:50

Matrix: Water

Date Received: 06/07/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 17:02
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 07:39

Client Sample ID: PV-2_75

Lab Sample ID: 410-175063-4

Date Collected: 06/06/24 09:55

Matrix: Water

Date Received: 06/07/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 17:15
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 07:51

Client Sample ID: SG1-FTB01-240606

Lab Sample ID: 410-175063-5

Date Collected: 06/06/24 10:00

Matrix: Water

Date Received: 06/07/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 17:29
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 08:02

Eurofins Lancaster Laboratories Environment Testing, LLC

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Client Sample ID: SG1-LTB01-240606
Date Collected: 06/06/24 00:00
Date Received: 06/07/24 09:45

Lab Sample ID: 410-175063-6
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			517788	D5VP	ELLE	06/16/24 14:07
Total/NA	Analysis	537 (Mod)		1	519504	FDE4	ELLE	06/20/24 17:42
Total/NA	Prep	537.1 DW Prep			515657	XBL5	ELLE	06/10/24 15:15
Total/NA	Analysis	EPA 537.1		1	517036	QD9Y	ELLE	06/14/24 08:14

Laboratory References:
ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Accreditation/Certification Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid

Method Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE
SPE	PFAS by SPE	Lab SOP	ELLE

Protocol References:

EPA = US Environmental Protection Agency
Lab SOP = Laboratory Standard Operating Procedure

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Sample Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-175063-1
SDG: HOO

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-175063-1	GAC INFLUENT	Water	06/06/24 09:45	06/07/24 09:45
410-175063-2	GAC MIDFLUENT	Water	06/06/24 09:48	06/07/24 09:45
410-175063-3	GAC EFFLUENT	Water	06/06/24 09:50	06/07/24 09:45
410-175063-4	PV-2_75	Water	06/06/24 09:55	06/07/24 09:45
410-175063-5	SG1-FTB01-240606	Water	06/06/24 10:00	06/07/24 09:45
410-175063-6	SG1-LTB01-240606	Water	06/06/24 00:00	06/07/24 09:45

Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-175063-1

SDG Number: HOO

Login Number: 175063

List Number: 1

Creator: Reiff, Nicole L

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable,where thermal pres is required(</=6C, not frozen).	True	
Cooler Temperature is recorded.	True	
WV:Container Temp acceptable,where thermal pres is required (</=6C, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	True	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	