

ANALYTICAL REPORT

PREPARED FOR

Attn: Jonathan Dippert
CT Male Associates DPC
50 Century Hill Dr
Latham, New York 12110

Generated 10/17/2024 3:17:35 PM

JOB DESCRIPTION

Hoosick Falls WTP
HOO

JOB NUMBER

410-189982-1

Eurofins Lancaster Laboratories Environment Testing, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
10/17/2024 3:17:35 PM

Authorized for release by
Kelly Gallagher, Project Manager
kelly.gallagher@et.eurofinsus.com
(717)205-7820

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.

- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.



Table of Contents

Cover Page 1

Table of Contents 4

Definitions/Glossary 5

Case Narrative 6

Detection Summary 7

Client Sample Results 8

Surrogate Summary 16

Isotope Dilution Summary 17

QC Sample Results 18

QC Association Summary 23

Lab Chronicle 25

Certification Summary 27

Method Summary 28

Sample Summary 29

Chain of Custody 30

Receipt Checklists 31



Definitions/Glossary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Qualifiers

LCMS

Qualifier	Qualifier Description
*3	ISTD response or retention time outside acceptable limits.
cn	Refer to Case Narrative for further detail
S1-	Surrogate recovery exceeds control limits, low biased.
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: CT Male Associates DPC
Project: Hoosick Falls WTP

Job ID: 410-189982-1

Job ID: 410-189982-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-189982-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 9/27/2024 9:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was -0.3°C.

PFAS

Method 537.1_DW: The recoveries for 13C2 PFDA, 13C2 PFHxA and d5-NEtFOSAA in SG1-FTB01-240926 (410-189982-7) and SG1-LTB01-240926 (410-189982-8) are below the QC acceptance limits. These samples were re-extracted outside of the required holding time and the recoveries for the labeled isotopes were within the QC acceptance limits.

Method 537.1_DW: The sample injection standard peak areas in SG1-LTB01-240926 (410-189982-8) are above the QC limits for the initial injection. This sample was re-extracted outside of the required holding time and the sample injection standard peak areas were within the QC acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-189982-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	3.7		1.9	ng/L	1		537 (Mod)	Total/NA
Perfluoropentanoic acid	3.1		1.9	ng/L	1		537 (Mod)	Total/NA
Perfluoroheptanoic acid	8.9		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorohexanoic acid	8.1		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanesulfonic acid	3.7		1.8	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanoic acid - DL	320		18	ng/L	10		EPA 537.1	Total/NA

Client Sample ID: GAC MIDLFUENT

Lab Sample ID: 410-189982-2

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	5.8		1.8	ng/L	1		537 (Mod)	Total/NA

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-189982-3

No Detections.

Client Sample ID: PV-1_25

Lab Sample ID: 410-189982-4

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	6.6		1.8	ng/L	1		537 (Mod)	Total/NA

Client Sample ID: PV-1_50

Lab Sample ID: 410-189982-5

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	2.2		1.8	ng/L	1		537 (Mod)	Total/NA

Client Sample ID: PV-1_75

Lab Sample ID: 410-189982-6

No Detections.

Client Sample ID: SG1-FTB01-240926

Lab Sample ID: 410-189982-7

No Detections.

Client Sample ID: SG1-LTB01-240926

Lab Sample ID: 410-189982-8

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-189982-1

Date Collected: 09/26/24 13:15

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
Perfluorobutanoic acid	3.7		1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1
Perfluoropentanoic acid	3.1		1.9	ng/L		10/11/24 16:36	10/15/24 12:29	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	89		26 - 200	10/11/24 16:36	10/15/24 12:29	1
M2-8:2 FTS	90		27 - 200	10/11/24 16:36	10/15/24 12:29	1
13C4 PFBA	99		10 - 168	10/11/24 16:36	10/15/24 12:29	1
13C5 PFPeA	105		15 - 189	10/11/24 16:36	10/15/24 12:29	1
13C8 PFOS	111		44 - 153	10/11/24 16:36	10/15/24 12:29	1
13C8 FOSA	86		11 - 149	10/11/24 16:36	10/15/24 12:29	1
13C3 PFHxS	117		39 - 164	10/11/24 16:36	10/15/24 12:29	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluoroheptanoic acid	8.9		1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorohexanoic acid	8.1		1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorooctanesulfonic acid	3.7		1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:24	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	113		70 - 130	10/01/24 15:11	10/10/24 07:24	1
13C2 PFHxA	114		70 - 130	10/01/24 15:11	10/10/24 07:24	1
d5-NEtFOSAA	111		70 - 130	10/01/24 15:11	10/10/24 07:24	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 - DL

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanoic acid	320		18	ng/L		10/01/24 15:11	10/10/24 15:55	10

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	93		70 - 130	10/01/24 15:11	10/10/24 15:55	10
13C2 PFHxA	102		70 - 130	10/01/24 15:11	10/10/24 15:55	10
d5-NEtFOSAA	106		70 - 130	10/01/24 15:11	10/10/24 15:55	10

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: GAC MIDLFUENT

Lab Sample ID: 410-189982-2

Date Collected: 09/26/24 13:20

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
Perfluorobutanoic acid	5.8		1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:43	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	70		26 - 200	10/11/24 16:36	10/15/24 12:43	1
M2-8:2 FTS	78		27 - 200	10/11/24 16:36	10/15/24 12:43	1
13C4 PFBA	91		10 - 168	10/11/24 16:36	10/15/24 12:43	1
13C5 PFPeA	88		15 - 189	10/11/24 16:36	10/15/24 12:43	1
13C8 PFOS	96		44 - 153	10/11/24 16:36	10/15/24 12:43	1
13C8 FOSA	79		11 - 149	10/11/24 16:36	10/15/24 12:43	1
13C3 PFHxS	98		39 - 164	10/11/24 16:36	10/15/24 12:43	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	100		70 - 130	10/01/24 15:11	10/10/24 07:37	1
13C2 PFHxA	112		70 - 130	10/01/24 15:11	10/10/24 07:37	1
d5-NEtFOSAA	90		70 - 130	10/01/24 15:11	10/10/24 07:37	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-189982-3

Date Collected: 09/26/24 13:25

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
Perfluorobutanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 12:56	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	86		26 - 200	10/11/24 16:36	10/15/24 12:56	1
M2-8:2 FTS	89		27 - 200	10/11/24 16:36	10/15/24 12:56	1
13C4 PFBA	114		10 - 168	10/11/24 16:36	10/15/24 12:56	1
13C5 PFPeA	107		15 - 189	10/11/24 16:36	10/15/24 12:56	1
13C8 PFOS	117		44 - 153	10/11/24 16:36	10/15/24 12:56	1
13C8 FOSA	93		11 - 149	10/11/24 16:36	10/15/24 12:56	1
13C3 PFHxS	120		39 - 164	10/11/24 16:36	10/15/24 12:56	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 07:51	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	99		70 - 130	10/01/24 15:11	10/10/24 07:51	1
13C2 PFHxA	109		70 - 130	10/01/24 15:11	10/10/24 07:51	1
d5-NEtFOSAA	97		70 - 130	10/01/24 15:11	10/10/24 07:51	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: PV-1_25

Lab Sample ID: 410-189982-4

Date Collected: 09/26/24 13:30

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
Perfluorobutanoic acid	6.6		1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:10	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	69		26 - 200	10/11/24 16:36	10/15/24 13:10	1
M2-8:2 FTS	107		27 - 200	10/11/24 16:36	10/15/24 13:10	1
13C4 PFBA	83		10 - 168	10/11/24 16:36	10/15/24 13:10	1
13C5 PFPeA	87		15 - 189	10/11/24 16:36	10/15/24 13:10	1
13C8 PFOS	97		44 - 153	10/11/24 16:36	10/15/24 13:10	1
13C8 FOSA	81		11 - 149	10/11/24 16:36	10/15/24 13:10	1
13C3 PFHxS	100		39 - 164	10/11/24 16:36	10/15/24 13:10	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 15:11	10/10/24 08:04	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	102		70 - 130	10/01/24 15:11	10/10/24 08:04	1
13C2 PFHxA	116		70 - 130	10/01/24 15:11	10/10/24 08:04	1
d5-NEtFOSAA	85		70 - 130	10/01/24 15:11	10/10/24 08:04	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: PV-1_50

Lab Sample ID: 410-189982-5

Date Collected: 09/26/24 13:35

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
Perfluorobutanoic acid	2.2		1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:23	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	75		26 - 200	10/11/24 16:36	10/15/24 13:23	1
M2-8:2 FTS	105		27 - 200	10/11/24 16:36	10/15/24 13:23	1
13C4 PFBA	93		10 - 168	10/11/24 16:36	10/15/24 13:23	1
13C5 PFPeA	90		15 - 189	10/11/24 16:36	10/15/24 13:23	1
13C8 PFOS	100		44 - 153	10/11/24 16:36	10/15/24 13:23	1
13C8 FOSA	83		11 - 149	10/11/24 16:36	10/15/24 13:23	1
13C3 PFHxS	103		39 - 164	10/11/24 16:36	10/15/24 13:23	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
NMeFOSAA	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		10/01/24 17:12	10/11/24 04:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	91		70 - 130	10/01/24 17:12	10/11/24 04:48	1
13C2 PFHxA	120		70 - 130	10/01/24 17:12	10/11/24 04:48	1
d5-NEtFOSAA	100		70 - 130	10/01/24 17:12	10/11/24 04:48	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: PV-1_75

Lab Sample ID: 410-189982-6

Date Collected: 09/26/24 13:40

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
Perfluorobutanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 13:37	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	80		26 - 200	10/11/24 16:36	10/15/24 13:37	1
M2-8:2 FTS	84		27 - 200	10/11/24 16:36	10/15/24 13:37	1
13C4 PFBA	103		10 - 168	10/11/24 16:36	10/15/24 13:37	1
13C5 PFPeA	102		15 - 189	10/11/24 16:36	10/15/24 13:37	1
13C8 PFOS	106		44 - 153	10/11/24 16:36	10/15/24 13:37	1
13C8 FOSA	92		11 - 149	10/11/24 16:36	10/15/24 13:37	1
13C3 PFHxS	109		39 - 164	10/11/24 16:36	10/15/24 13:37	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	103		70 - 130	10/01/24 17:12	10/11/24 05:02	1
13C2 PFHxA	118		70 - 130	10/01/24 17:12	10/11/24 05:02	1
d5-NEtFOSAA	113		70 - 130	10/01/24 17:12	10/11/24 05:02	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: SG1-FTB01-240926

Lab Sample ID: 410-189982-7

Date Collected: 09/26/24 13:45

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		10/11/24 16:36	10/16/24 18:11	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	114		26 - 200	10/11/24 16:36	10/16/24 18:11	1
M2-8:2 FTS	123		27 - 200	10/11/24 16:36	10/16/24 18:11	1
13C4 PFBA	106		10 - 168	10/11/24 16:36	10/16/24 18:11	1
13C5 PFPeA	106		15 - 189	10/11/24 16:36	10/16/24 18:11	1
13C8 PFOS	112		44 - 153	10/11/24 16:36	10/16/24 18:11	1
13C8 FOSA	96		11 - 149	10/11/24 16:36	10/16/24 18:11	1
13C3 PFHxS	117		39 - 164	10/11/24 16:36	10/16/24 18:11	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
NMeFOSAA	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		10/01/24 17:12	10/11/24 05:15	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	63	S1- cn	70 - 130	10/01/24 17:12	10/11/24 05:15	1
13C2 PFHxA	31	S1- cn	70 - 130	10/01/24 17:12	10/11/24 05:15	1
d5-NEtFOSAA	24	S1- cn	70 - 130	10/01/24 17:12	10/11/24 05:15	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: SG1-LTB01-240926

Lab Sample ID: 410-189982-8

Date Collected: 09/26/24 00:00

Matrix: Water

Date Received: 09/27/24 09:45

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
8:2 Fluorotelomer sulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
Perfluorobutanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
Perfluorodecanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
Perfluoroheptanesulfonic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
Perfluorooctanesulfonamide	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1
Perfluoropentanoic acid	1.8	U	1.8	ng/L		10/11/24 16:36	10/15/24 14:17	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	86		26 - 200	10/11/24 16:36	10/15/24 14:17	1
M2-8:2 FTS	124		27 - 200	10/11/24 16:36	10/15/24 14:17	1
13C4 PFBA	116		10 - 168	10/11/24 16:36	10/15/24 14:17	1
13C5 PFPeA	107		15 - 189	10/11/24 16:36	10/15/24 14:17	1
13C8 PFOS	116		44 - 153	10/11/24 16:36	10/15/24 14:17	1
13C8 FOSA	99		11 - 149	10/11/24 16:36	10/15/24 14:17	1
13C3 PFHxS	120		39 - 164	10/11/24 16:36	10/15/24 14:17	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
NMeFOSAA	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorobutanesulfonic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorodecanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorododecanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluoroheptanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorohexanesulfonic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorohexanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorononanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorooctanesulfonic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorooctanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorotetradecanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluorotridecanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1
Perfluoroundecanoic acid	1.8	U *3 cn	1.8	ng/L		10/01/24 17:12	10/11/24 05:28	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	69	S1- *3 cn	70 - 130	10/01/24 17:12	10/11/24 05:28	1
13C2 PFHxA	31	S1- *3 cn	70 - 130	10/01/24 17:12	10/11/24 05:28	1
d5-NEtFOSAA	23	S1- *3 cn	70 - 130	10/01/24 17:12	10/11/24 05:28	1

Surrogate Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		PFDA (70-130)	PFHxA (70-130)	d5NEFOS (70-130)
410-189982-1 - DL	GAC INFLUENT	93	102	106
410-189982-1	GAC INFLUENT	113	114	111
410-189982-2	GAC MIDLFUENT	100	112	90
410-189982-3	GAC EFFLUENT	99	109	97
410-189982-4	PV-1_25	102	116	85
410-189982-5	PV-1_50	91	120	100
410-189982-6	PV-1_75	103	118	113
410-189982-7	SG1-FTB01-240926	63 S1- cn	31 S1- cn	24 S1- cn
410-189982-8	SG1-LTB01-240926	69 S1- *3 cn	31 S1- *3 cn	23 S1- *3 cn
LCS 410-558013/2-A	Lab Control Sample	111	111	114
LCS 410-558084/2-A	Lab Control Sample	106	104	99
LCSD 410-558013/3-A	Lab Control Sample Dup	110	109	100
LCSD 410-558084/3-A	Lab Control Sample Dup	104	102	90
MB 410-558013/1-A	Method Blank	102	107	98
MB 410-558084/1-A	Method Blank	103	122	103
Surrogate Legend				
PFDA = 13C2 PFDA				
PFHxA = 13C2 PFHxA				
d5NEFOS = d5-NEtFOSAA				

Isotope Dilution Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)						
		M262FTS (26-200)	M282FTS (27-200)	PFBA (10-168)	PFPeA (15-189)	C8PFOS (44-153)	PFOSA (11-149)	C3PFHS (39-164)
410-189982-1	GAC INFLUENT	89	90	99	105	111	86	117
410-189982-2	GAC MIDLFUENT	70	78	91	88	96	79	98
410-189982-3	GAC EFFLUENT	86	89	114	107	117	93	120
410-189982-4	PV-1_25	69	107	83	87	97	81	100
410-189982-5	PV-1_50	75	105	93	90	100	83	103
410-189982-6	PV-1_75	80	84	103	102	106	92	109
410-189982-7	SG1-FTB01-240926	114	123	106	106	112	96	117
410-189982-8	SG1-LTB01-240926	86	124	116	107	116	99	120
LCS 410-562330/2-A	Lab Control Sample	73	76	78	93	103	86	103
LCSD 410-562330/3-A	Lab Control Sample Dup	94	100	101	115	125	111	124
MB 410-562330/1-A	Method Blank	71	75	76	90	98	77	99

Surrogate Legend

M262FTS = M2-6:2 FTS

M282FTS = M2-8:2 FTS

PFBA = 13C4 PFBA

PFPeA = 13C5 PFPeA

C8PFOS = 13C8 PFOS

PFOSA = 13C8 FOSA

C3PFHS = 13C3 PFHxS

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Lab Sample ID: MB 410-562330/1-A

Matrix: Water

Analysis Batch: 563246

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 562330

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		10/11/24 16:36	10/15/24 11:08	1

Isotope Dilution	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	71		26 - 200	10/11/24 16:36	10/15/24 11:08	1
M2-8:2 FTS	75		27 - 200	10/11/24 16:36	10/15/24 11:08	1
13C4 PFBA	76		10 - 168	10/11/24 16:36	10/15/24 11:08	1
13C5 PFPeA	90		15 - 189	10/11/24 16:36	10/15/24 11:08	1
13C8 PFOS	98		44 - 153	10/11/24 16:36	10/15/24 11:08	1
13C8 FOSA	77		11 - 149	10/11/24 16:36	10/15/24 11:08	1
13C3 PFHxS	99		39 - 164	10/11/24 16:36	10/15/24 11:08	1

Lab Sample ID: LCS 410-562330/2-A

Matrix: Water

Analysis Batch: 563246

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 562330

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
6:2 Fluorotelomer sulfonic acid	24.3	23.7		ng/L		98	61 - 132
8:2 Fluorotelomer sulfonic acid	24.5	23.6		ng/L		96	55 - 134
Perfluorobutanoic acid	25.6	25.0		ng/L		98	58 - 130
Perfluorodecanesulfonic acid	24.7	24.0		ng/L		97	55 - 130
Perfluoroheptanesulfonic acid	24.4	24.4		ng/L		100	59 - 130
Perfluorooctanesulfonamide	25.6	24.4		ng/L		95	67 - 132
Perfluoropentanoic acid	25.6	26.2		ng/L		102	60 - 130

Isotope Dilution	LCS %Recovery	LCS Qualifier	Limits
M2-6:2 FTS	73		26 - 200
M2-8:2 FTS	76		27 - 200
13C4 PFBA	78		10 - 168
13C5 PFPeA	93		15 - 189
13C8 PFOS	103		44 - 153
13C8 FOSA	86		11 - 149
13C3 PFHxS	103		39 - 164

Lab Sample ID: LCSD 410-562330/3-A

Matrix: Water

Analysis Batch: 563246

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 562330

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
6:2 Fluorotelomer sulfonic acid	24.3	21.7		ng/L		89	61 - 132	9	30
8:2 Fluorotelomer sulfonic acid	24.5	22.5		ng/L		92	55 - 134	5	30
Perfluorobutanoic acid	25.6	25.1		ng/L		98	58 - 130	0	30
Perfluorodecanesulfonic acid	24.7	22.8		ng/L		92	55 - 130	5	30
Perfluoroheptanesulfonic acid	24.4	25.6		ng/L		105	59 - 130	5	30

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified (Continued)

Lab Sample ID: LCSD 410-562330/3-A

Matrix: Water

Analysis Batch: 563246

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 562330

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorooctanesulfonamide	25.6	24.8		ng/L		97	67 - 132	2	30
Perfluoropentanoic acid	25.6	24.7		ng/L		97	60 - 130	6	30

Isotope Dilution	LCSD %Recovery	LCSD Qualifier	Limits
M2-6:2 FTS	94		26 - 200
M2-8:2 FTS	100		27 - 200
13C4 PFBA	101		10 - 168
13C5 PFPeA	115		15 - 189
13C8 PFOS	125		44 - 153
13C8 FOSA	111		11 - 149
13C3 PFHxS	124		39 - 164

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Lab Sample ID: MB 410-558013/1-A

Matrix: Water

Analysis Batch: 561411

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 558013

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
NMeFOSAA	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		10/01/24 15:11	10/10/24 03:22	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	102		70 - 130	10/01/24 15:11	10/10/24 03:22	1
13C2 PFHxA	107		70 - 130	10/01/24 15:11	10/10/24 03:22	1
d5-NEtFOSAA	98		70 - 130	10/01/24 15:11	10/10/24 03:22	1

Lab Sample ID: LCS 410-558013/2-A

Matrix: Water

Analysis Batch: 561411

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 558013

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
NEtFOSAA	60.0	62.3		ng/L		104	70 - 130
NMeFOSAA	60.0	64.0		ng/L		107	70 - 130
Perfluorobutanesulfonic acid	53.1	49.3		ng/L		93	70 - 130
Perfluorodecanoic acid	60.0	61.6		ng/L		103	70 - 130
Perfluorododecanoic acid	60.0	62.8		ng/L		105	70 - 130

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCS 410-558013/2-A

Matrix: Water

Analysis Batch: 561411

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 558013

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				Limits
Perfluoroheptanoic acid	60.0	60.4		ng/L		101	70 - 130
Perfluorohexanesulfonic acid	54.7	53.6		ng/L		98	70 - 130
Perfluorohexanoic acid	60.0	59.8		ng/L		100	70 - 130
Perfluorononanoic acid	60.0	61.0		ng/L		102	70 - 130
Perfluorooctanesulfonic acid	55.5	52.6		ng/L		95	70 - 130
Perfluorooctanoic acid	60.0	64.6		ng/L		108	70 - 130
Perfluorotetradecanoic acid	60.0	57.4		ng/L		96	70 - 130
Perfluorotridecanoic acid	60.0	60.7		ng/L		101	70 - 130
Perfluoroundecanoic acid	60.0	61.1		ng/L		102	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
13C2 PFDA	111		70 - 130
13C2 PFHxA	111		70 - 130
d5-NEtFOSAA	114		70 - 130

Lab Sample ID: LCSD 410-558013/3-A

Matrix: Water

Analysis Batch: 561411

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 558013

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	Limit
	Added	Result	Qualifier						
NEtFOSAA	60.0	57.5		ng/L		96	70 - 130	8	30
NMeFOSAA	60.0	52.1		ng/L		87	70 - 130	21	30
Perfluorobutanesulfonic acid	53.1	51.7		ng/L		97	70 - 130	5	30
Perfluorodecanoic acid	60.0	68.0		ng/L		113	70 - 130	10	30
Perfluorododecanoic acid	60.0	57.8		ng/L		96	70 - 130	8	30
Perfluoroheptanoic acid	60.0	63.2		ng/L		105	70 - 130	5	30
Perfluorohexanesulfonic acid	54.7	55.3		ng/L		101	70 - 130	3	30
Perfluorohexanoic acid	60.0	60.4		ng/L		101	70 - 130	1	30
Perfluorononanoic acid	60.0	62.9		ng/L		105	70 - 130	3	30
Perfluorooctanesulfonic acid	55.5	54.6		ng/L		98	70 - 130	4	30
Perfluorooctanoic acid	60.0	62.8		ng/L		105	70 - 130	3	30
Perfluorotetradecanoic acid	60.0	59.5		ng/L		99	70 - 130	4	30
Perfluorotridecanoic acid	60.0	57.5		ng/L		96	70 - 130	5	30
Perfluoroundecanoic acid	60.0	63.5		ng/L		106	70 - 130	4	30

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
13C2 PFDA	110		70 - 130
13C2 PFHxA	109		70 - 130
d5-NEtFOSAA	100		70 - 130

Lab Sample ID: MB 410-558084/1-A

Matrix: Water

Analysis Batch: 561810

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 558084

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
NEtFOSAA	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
NMeFOSAA	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: MB 410-558084/1-A

Matrix: Water

Analysis Batch: 561810

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 558084

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorodecanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		10/01/24 17:12	10/11/24 03:01	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	103		70 - 130	10/01/24 17:12	10/11/24 03:01	1
13C2 PFHxA	122		70 - 130	10/01/24 17:12	10/11/24 03:01	1
d5-NEtFOSAA	103		70 - 130	10/01/24 17:12	10/11/24 03:01	1

Lab Sample ID: LCS 410-558084/2-A

Matrix: Water

Analysis Batch: 561810

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 558084

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
NEtFOSAA	20.5	15.9		ng/L		78	70 - 130
NMeFOSAA	20.5	16.6		ng/L		81	70 - 130
Perfluorobutanesulfonic acid	18.1	16.3		ng/L		90	70 - 130
Perfluorodecanoic acid	20.5	19.7		ng/L		96	70 - 130
Perfluorododecanoic acid	20.5	17.1		ng/L		83	70 - 130
Perfluoroheptanoic acid	20.5	21.6		ng/L		106	70 - 130
Perfluorohexanesulfonic acid	18.7	20.0		ng/L		107	70 - 130
Perfluorohexanoic acid	20.5	18.9		ng/L		92	70 - 130
Perfluorononanoic acid	20.5	21.3		ng/L		104	70 - 130
Perfluorooctanesulfonic acid	19.0	19.1		ng/L		101	70 - 130
Perfluorooctanoic acid	20.5	20.0		ng/L		98	70 - 130
Perfluorotetradecanoic acid	20.5	19.1		ng/L		93	70 - 130
Perfluorotridecanoic acid	20.5	18.0		ng/L		88	70 - 130
Perfluoroundecanoic acid	20.5	20.3		ng/L		99	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
13C2 PFDA	106		70 - 130
13C2 PFHxA	104		70 - 130
d5-NEtFOSAA	99		70 - 130

Lab Sample ID: LCSD 410-558084/3-A

Matrix: Water

Analysis Batch: 561810

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 558084

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
NEtFOSAA	20.5	16.6		ng/L		81	70 - 130	4	30

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCSD 410-558084/3-A

Matrix: Water

Analysis Batch: 561810

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 558084

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
NMeFOSAA	20.5	16.5		ng/L		80	70 - 130	1	30
Perfluorobutanesulfonic acid	18.1	16.4		ng/L		90	70 - 130	0	30
Perfluorodecanoic acid	20.5	18.9		ng/L		92	70 - 130	4	30
Perfluorododecanoic acid	20.5	18.2		ng/L		89	70 - 130	6	30
Perfluoroheptanoic acid	20.5	21.9		ng/L		107	70 - 130	1	30
Perfluorohexanesulfonic acid	18.7	20.6		ng/L		110	70 - 130	3	30
Perfluorohexanoic acid	20.5	19.2		ng/L		94	70 - 130	2	30
Perfluorononanoic acid	20.5	20.6		ng/L		101	70 - 130	3	30
Perfluorooctanesulfonic acid	19.0	20.2		ng/L		107	70 - 130	6	30
Perfluorooctanoic acid	20.5	20.4		ng/L		99	70 - 130	2	30
Perfluorotetradecanoic acid	20.5	18.5		ng/L		90	70 - 130	3	30
Perfluorotridecanoic acid	20.5	16.9		ng/L		83	70 - 130	6	30
Perfluoroundecanoic acid	20.5	19.2		ng/L		94	70 - 130	6	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
13C2 PFDA	104		70 - 130
13C2 PFHxA	102		70 - 130
d5-NEtFOSAA	90		70 - 130

QC Association Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

LCMS

Prep Batch: 558013

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-1 - DL	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-189982-1	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-189982-2	GAC MIDLFUENT	Total/NA	Water	537.1 DW Prep	
410-189982-3	GAC EFFLUENT	Total/NA	Water	537.1 DW Prep	
410-189982-4	PV-1_25	Total/NA	Water	537.1 DW Prep	
MB 410-558013/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-558013/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-558013/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

Prep Batch: 558084

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-5	PV-1_50	Total/NA	Water	537.1 DW Prep	
410-189982-6	PV-1_75	Total/NA	Water	537.1 DW Prep	
410-189982-7	SG1-FTB01-240926	Total/NA	Water	537.1 DW Prep	
410-189982-8	SG1-LTB01-240926	Total/NA	Water	537.1 DW Prep	
MB 410-558084/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-558084/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-558084/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

Analysis Batch: 561411

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-1	GAC INFLUENT	Total/NA	Water	EPA 537.1	558013
410-189982-1 - DL	GAC INFLUENT	Total/NA	Water	EPA 537.1	558013
410-189982-2	GAC MIDLFUENT	Total/NA	Water	EPA 537.1	558013
410-189982-3	GAC EFFLUENT	Total/NA	Water	EPA 537.1	558013
410-189982-4	PV-1_25	Total/NA	Water	EPA 537.1	558013
MB 410-558013/1-A	Method Blank	Total/NA	Water	EPA 537.1	558013
LCS 410-558013/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	558013
LCSD 410-558013/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	558013

Analysis Batch: 561810

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-5	PV-1_50	Total/NA	Water	EPA 537.1	558084
410-189982-6	PV-1_75	Total/NA	Water	EPA 537.1	558084
410-189982-7	SG1-FTB01-240926	Total/NA	Water	EPA 537.1	558084
410-189982-8	SG1-LTB01-240926	Total/NA	Water	EPA 537.1	558084
MB 410-558084/1-A	Method Blank	Total/NA	Water	EPA 537.1	558084
LCS 410-558084/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	558084
LCSD 410-558084/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	558084

Prep Batch: 562330

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-1	GAC INFLUENT	Total/NA	Water	SPE	
410-189982-2	GAC MIDLFUENT	Total/NA	Water	SPE	
410-189982-3	GAC EFFLUENT	Total/NA	Water	SPE	
410-189982-4	PV-1_25	Total/NA	Water	SPE	
410-189982-5	PV-1_50	Total/NA	Water	SPE	
410-189982-6	PV-1_75	Total/NA	Water	SPE	
410-189982-7	SG1-FTB01-240926	Total/NA	Water	SPE	
410-189982-8	SG1-LTB01-240926	Total/NA	Water	SPE	
MB 410-562330/1-A	Method Blank	Total/NA	Water	SPE	

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Association Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

LCMS (Continued)

Prep Batch: 562330 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCS 410-562330/2-A	Lab Control Sample	Total/NA	Water	SPE	
LCSD 410-562330/3-A	Lab Control Sample Dup	Total/NA	Water	SPE	

Prep Batch: 562730

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-7 - RE	SG1-FTB01-240926	Total/NA	Water	537.1 DW Prep	
410-189982-8 - RE	SG1-LTB01-240926	Total/NA	Water	537.1 DW Prep	
MB 410-562730/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-562730/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-562730/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

Analysis Batch: 563057

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-7 - RE	SG1-FTB01-240926	Total/NA	Water	EPA 537.1	562730
410-189982-8 - RE	SG1-LTB01-240926	Total/NA	Water	EPA 537.1	562730
MB 410-562730/1-A	Method Blank	Total/NA	Water	EPA 537.1	562730
LCS 410-562730/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	562730
LCSD 410-562730/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	562730

Analysis Batch: 563246

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-1	GAC INFLUENT	Total/NA	Water	537 (Mod)	562330
410-189982-2	GAC MIDLFUENT	Total/NA	Water	537 (Mod)	562330
410-189982-3	GAC EFFLUENT	Total/NA	Water	537 (Mod)	562330
410-189982-4	PV-1_25	Total/NA	Water	537 (Mod)	562330
410-189982-5	PV-1_50	Total/NA	Water	537 (Mod)	562330
410-189982-6	PV-1_75	Total/NA	Water	537 (Mod)	562330
410-189982-8	SG1-LTB01-240926	Total/NA	Water	537 (Mod)	562330
MB 410-562330/1-A	Method Blank	Total/NA	Water	537 (Mod)	562330
LCS 410-562330/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	562330
LCSD 410-562330/3-A	Lab Control Sample Dup	Total/NA	Water	537 (Mod)	562330

Analysis Batch: 563944

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-189982-7	SG1-FTB01-240926	Total/NA	Water	537 (Mod)	562330

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-189982-1

Date Collected: 09/26/24 13:15

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 12:29
Total/NA	Prep	537.1 DW Prep			558013	ULU3	ELLE	10/01/24 15:11
Total/NA	Analysis	EPA 537.1		1	561411	QD9Y	ELLE	10/10/24 07:24
Total/NA	Prep	537.1 DW Prep	DL		558013	ULU3	ELLE	10/01/24 15:11
Total/NA	Analysis	EPA 537.1	DL	10	561411	QD9Y	ELLE	10/10/24 15:55

Client Sample ID: GAC MIDLFUENT

Lab Sample ID: 410-189982-2

Date Collected: 09/26/24 13:20

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 12:43
Total/NA	Prep	537.1 DW Prep			558013	ULU3	ELLE	10/01/24 15:11
Total/NA	Analysis	EPA 537.1		1	561411	QD9Y	ELLE	10/10/24 07:37

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-189982-3

Date Collected: 09/26/24 13:25

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 12:56
Total/NA	Prep	537.1 DW Prep			558013	ULU3	ELLE	10/01/24 15:11
Total/NA	Analysis	EPA 537.1		1	561411	QD9Y	ELLE	10/10/24 07:51

Client Sample ID: PV-1_25

Lab Sample ID: 410-189982-4

Date Collected: 09/26/24 13:30

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 13:10
Total/NA	Prep	537.1 DW Prep			558013	ULU3	ELLE	10/01/24 15:11
Total/NA	Analysis	EPA 537.1		1	561411	QD9Y	ELLE	10/10/24 08:04

Client Sample ID: PV-1_50

Lab Sample ID: 410-189982-5

Date Collected: 09/26/24 13:35

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 13:23
Total/NA	Prep	537.1 DW Prep			558084	ULU3	ELLE	10/01/24 17:12
Total/NA	Analysis	EPA 537.1		1	561810	QD9Y	ELLE	10/11/24 04:48

Eurofins Lancaster Laboratories Environment Testing, LLC

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Client Sample ID: PV-1_75

Lab Sample ID: 410-189982-6

Date Collected: 09/26/24 13:40

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 13:37
Total/NA	Prep	537.1 DW Prep			558084	ULU3	ELLE	10/01/24 17:12
Total/NA	Analysis	EPA 537.1		1	561810	QD9Y	ELLE	10/11/24 05:02

Client Sample ID: SG1-FTB01-240926

Lab Sample ID: 410-189982-7

Date Collected: 09/26/24 13:45

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563944	R7RE	ELLE	10/16/24 18:11
Total/NA	Prep	537.1 DW Prep	RE		562730	HQ8B	ELLE	10/14/24 08:38
Total/NA	Analysis	EPA 537.1	RE	1	563057	WR4P	ELLE	10/15/24 13:35
Total/NA	Prep	537.1 DW Prep			558084	ULU3	ELLE	10/01/24 17:12
Total/NA	Analysis	EPA 537.1		1	561810	QD9Y	ELLE	10/11/24 05:15

Client Sample ID: SG1-LTB01-240926

Lab Sample ID: 410-189982-8

Date Collected: 09/26/24 00:00

Matrix: Water

Date Received: 09/27/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			562330	V3FW	ELLE	10/11/24 16:36
Total/NA	Analysis	537 (Mod)		1	563246	C6WW	ELLE	10/15/24 14:17
Total/NA	Prep	537.1 DW Prep	RE		562730	HQ8B	ELLE	10/14/24 08:38
Total/NA	Analysis	EPA 537.1	RE	1	563057	WR4P	ELLE	10/15/24 13:48
Total/NA	Prep	537.1 DW Prep			558084	ULU3	ELLE	10/01/24 17:12
Total/NA	Analysis	EPA 537.1		1	561810	QD9Y	ELLE	10/11/24 05:28

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Accreditation/Certification Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid

Method Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE
SPE	PFAS by SPE	Lab SOP	ELLE

Protocol References:

EPA = US Environmental Protection Agency
Lab SOP = Laboratory Standard Operating Procedure

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Sample Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-189982-1
SDG: HOO

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-189982-1	GAC INFLUENT	Water	09/26/24 13:15	09/27/24 09:45
410-189982-2	GAC MIDLFUENT	Water	09/26/24 13:20	09/27/24 09:45
410-189982-3	GAC EFFLUENT	Water	09/26/24 13:25	09/27/24 09:45
410-189982-4	PV-1_25	Water	09/26/24 13:30	09/27/24 09:45
410-189982-5	PV-1_50	Water	09/26/24 13:35	09/27/24 09:45
410-189982-6	PV-1_75	Water	09/26/24 13:40	09/27/24 09:45
410-189982-7	SG1-FTB01-240926	Water	09/26/24 13:45	09/27/24 09:45
410-189982-8	SG1-LTB01-240926	Water	09/26/24 00:00	09/27/24 09:45

Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-189982-1

SDG Number: HOO

Login Number: 189982

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

List Number: 1

Creator: Reiff, Nicole L

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable,where thermal pres is required(</=6C, not frozen).	True	
Cooler Temperature is recorded.	True	
WV:Container Temp acceptable,where thermal pres is required (</=6C, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	N/A	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	