

ANALYTICAL REPORT

PREPARED FOR

Attn: Jonathan Dippert
CT Male Associates DPC
50 Century Hill Dr
Latham, New York 12110

Generated 12/17/2024 8:38:15 AM

JOB DESCRIPTION

Hoosick Falls WTP
HOO

JOB NUMBER

410-199620-1

Eurofins Lancaster Laboratories Environment Testing, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
12/17/2024 8:38:15 AM

Authorized for release by
Kelly Gallagher, Project Manager
kelly.gallagher@et.eurofinsus.com
(717)205-7820

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
 - Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
 - Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.
- Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.



Table of Contents

Cover Page	1
Table of Contents	4
Definitions/Glossary	5
Case Narrative	6
Detection Summary	7
Client Sample Results	8
Surrogate Summary	13
Isotope Dilution Summary	14
QC Sample Results	15
QC Association Summary	18
Lab Chronicle	19
Certification Summary	21
Method Summary	22
Sample Summary	23
Chain of Custody	24
Receipt Checklists	25



Definitions/Glossary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Qualifiers

LCMS

Qualifier	Qualifier Description
cn	Refer to Case Narrative for further detail
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: CT Male Associates DPC
Project: Hoosick Falls WTP

Job ID: 410-199620-1

Job ID: 410-199620-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-199620-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 12/7/2024 9:40 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.4°C.

PFAS

Method 537.1_DW: The following sample was found to contain residual chlorine: GAC INFLUENT (410-199620-3).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: SG1-LTB01-241205

Lab Sample ID: 410-199620-1

No Detections.

Client Sample ID: SG1-FTB01-241205

Lab Sample ID: 410-199620-2

No Detections.

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-199620-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid	3.9		1.6	ng/L	1		537 (Mod)	Total/NA
Perfluoropentanoic acid	2.9		1.6	ng/L	1		537 (Mod)	Total/NA
Perfluoroheptanoic acid	8.0	cn	1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorohexanoic acid	8.0	cn	1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanesulfonic acid	3.6	cn	1.7	ng/L	1		EPA 537.1	Total/NA
Perfluorooctanoic acid - DL	400	cn	17	ng/L	10		EPA 537.1	Total/NA

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-199620-4

No Detections.

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-199620-5

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: SG1-LTB01-241205

Lab Sample ID: 410-199620-1

Date Collected: 12/05/24 00:00

Matrix: Water

Date Received: 12/07/24 09:40

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 04:52	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	96		26 - 200	12/10/24 06:53	12/14/24 04:52	1
M2-8:2 FTS	91		27 - 200	12/10/24 06:53	12/14/24 04:52	1
13C4 PFBA	64		10 - 168	12/10/24 06:53	12/14/24 04:52	1
13C5 PFPeA	79		15 - 189	12/10/24 06:53	12/14/24 04:52	1
13C8 PFOS	93		44 - 153	12/10/24 06:53	12/14/24 04:52	1
13C8 FOSA	85		11 - 149	12/10/24 06:53	12/14/24 04:52	1
13C3 PFHxS	89		39 - 164	12/10/24 06:53	12/14/24 04:52	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
NMeFOSAA	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 03:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	96		70 - 130	12/10/24 07:40	12/12/24 03:07	1
13C2 PFHxA	101		70 - 130	12/10/24 07:40	12/12/24 03:07	1
d5-NEtFOSAA	102		70 - 130	12/10/24 07:40	12/12/24 03:07	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: SG1-FTB01-241205

Lab Sample ID: 410-199620-2

Date Collected: 12/05/24 09:50

Matrix: Water

Date Received: 12/07/24 09:40

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
8:2 Fluorotelomer sulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
Perfluorobutanoic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
Perfluorodecanesulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
Perfluoroheptanesulfonic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
Perfluorooctanesulfonamide	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1
Perfluoropentanoic acid	1.9	U	1.9	ng/L		12/10/24 06:53	12/14/24 05:05	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	92		26 - 200	12/10/24 06:53	12/14/24 05:05	1
M2-8:2 FTS	88		27 - 200	12/10/24 06:53	12/14/24 05:05	1
13C4 PFBA	73		10 - 168	12/10/24 06:53	12/14/24 05:05	1
13C5 PFPeA	77		15 - 189	12/10/24 06:53	12/14/24 05:05	1
13C8 PFOS	90		44 - 153	12/10/24 06:53	12/14/24 05:05	1
13C8 FOSA	89		11 - 149	12/10/24 06:53	12/14/24 05:05	1
13C3 PFHxS	87		39 - 164	12/10/24 06:53	12/14/24 05:05	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
NMeFOSAA	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorobutanesulfonic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorodecanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorododecanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluoroheptanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorohexanesulfonic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorohexanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorononanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorooctanesulfonic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorooctanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorotetradecanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluorotridecanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1
Perfluoroundecanoic acid	1.8	U	1.8	ng/L		12/10/24 07:40	12/12/24 03:20	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	93		70 - 130	12/10/24 07:40	12/12/24 03:20	1
13C2 PFHxA	101		70 - 130	12/10/24 07:40	12/12/24 03:20	1
d5-NEtFOSAA	98		70 - 130	12/10/24 07:40	12/12/24 03:20	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-199620-3

Date Collected: 12/05/24 10:00

Matrix: Water

Date Received: 12/07/24 09:40

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
8:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
Perfluorobutanoic acid	3.9		1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
Perfluorodecanesulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
Perfluoroheptanesulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
Perfluorooctanesulfonamide	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1
Perfluoropentanoic acid	2.9		1.6	ng/L		12/10/24 06:53	12/14/24 05:19	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	105		26 - 200	12/10/24 06:53	12/14/24 05:19	1
M2-8:2 FTS	94		27 - 200	12/10/24 06:53	12/14/24 05:19	1
13C4 PFBA	59		10 - 168	12/10/24 06:53	12/14/24 05:19	1
13C5 PFPeA	102		15 - 189	12/10/24 06:53	12/14/24 05:19	1
13C8 PFOS	95		44 - 153	12/10/24 06:53	12/14/24 05:19	1
13C8 FOSA	86		11 - 149	12/10/24 06:53	12/14/24 05:19	1
13C3 PFHxS	102		39 - 164	12/10/24 06:53	12/14/24 05:19	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
NMeFOSAA	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorobutanesulfonic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorodecanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorododecanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluoroheptanoic acid	8.0	cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorohexanesulfonic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorohexanoic acid	8.0	cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorononanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorooctanesulfonic acid	3.6	cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorotetradecanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluorotridecanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1
Perfluoroundecanoic acid	1.7	U cn	1.7	ng/L		12/10/24 07:40	12/12/24 03:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	105	cn	70 - 130	12/10/24 07:40	12/12/24 03:34	1
13C2 PFHxA	109	cn	70 - 130	12/10/24 07:40	12/12/24 03:34	1
d5-NEtFOSAA	93	cn	70 - 130	12/10/24 07:40	12/12/24 03:34	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 - DL

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorooctanoic acid	400	cn	17	ng/L		12/10/24 07:40	12/13/24 00:52	10

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	119	cn	70 - 130	12/10/24 07:40	12/13/24 00:52	10
13C2 PFHxA	121	cn	70 - 130	12/10/24 07:40	12/13/24 00:52	10
d5-NEtFOSAA	112	cn	70 - 130	12/10/24 07:40	12/13/24 00:52	10

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-199620-4

Date Collected: 12/05/24 10:12

Matrix: Water

Date Received: 12/07/24 09:40

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
8:2 Fluorotelomer sulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
Perfluorobutanoic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
Perfluorodecanesulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
Perfluoroheptanesulfonic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
Perfluorooctanesulfonamide	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1
Perfluoropentanoic acid	1.6	U	1.6	ng/L		12/10/24 06:53	12/14/24 05:32	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	91		26 - 200	12/10/24 06:53	12/14/24 05:32	1
M2-8:2 FTS	81		27 - 200	12/10/24 06:53	12/14/24 05:32	1
13C4 PFBA	76		10 - 168	12/10/24 06:53	12/14/24 05:32	1
13C5 PFPeA	81		15 - 189	12/10/24 06:53	12/14/24 05:32	1
13C8 PFOS	89		44 - 153	12/10/24 06:53	12/14/24 05:32	1
13C8 FOSA	85		11 - 149	12/10/24 06:53	12/14/24 05:32	1
13C3 PFHxS	88		39 - 164	12/10/24 06:53	12/14/24 05:32	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
NMeFOSAA	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 03:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	97		70 - 130	12/10/24 07:40	12/12/24 03:47	1
13C2 PFHxA	102		70 - 130	12/10/24 07:40	12/12/24 03:47	1
d5-NEtFOSAA	96		70 - 130	12/10/24 07:40	12/12/24 03:47	1

Client Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-199620-5

Date Collected: 12/05/24 10:21

Matrix: Water

Date Received: 12/07/24 09:40

Method: EPA 537 (Mod) - EPA 537 Version 1.1 modified

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
8:2 Fluorotelomer sulfonic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
Perfluorobutanoic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
Perfluorodecanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
Perfluoroheptanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
Perfluorooctanesulfonamide	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1
Perfluoropentanoic acid	1.7	U	1.7	ng/L		12/10/24 06:53	12/14/24 05:46	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	90		26 - 200	12/10/24 06:53	12/14/24 05:46	1
M2-8:2 FTS	90		27 - 200	12/10/24 06:53	12/14/24 05:46	1
13C4 PFBA	69		10 - 168	12/10/24 06:53	12/14/24 05:46	1
13C5 PFPeA	82		15 - 189	12/10/24 06:53	12/14/24 05:46	1
13C8 PFOS	88		44 - 153	12/10/24 06:53	12/14/24 05:46	1
13C8 FOSA	91		11 - 149	12/10/24 06:53	12/14/24 05:46	1
13C3 PFHxS	88		39 - 164	12/10/24 06:53	12/14/24 05:46	1

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
NMeFOSAA	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorobutanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorodecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorododecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluoroheptanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorohexanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorohexanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorononanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorooctanesulfonic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorooctanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorotetradecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluorotridecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1
Perfluoroundecanoic acid	1.7	U	1.7	ng/L		12/10/24 07:40	12/12/24 04:01	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	98		70 - 130	12/10/24 07:40	12/12/24 04:01	1
13C2 PFHxA	99		70 - 130	12/10/24 07:40	12/12/24 04:01	1
d5-NEtFOSAA	99		70 - 130	12/10/24 07:40	12/12/24 04:01	1

Surrogate Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Matrix: Water

Prep Type: Total/NA

		Percent Surrogate Recovery (Acceptance Limits)		
Lab Sample ID	Client Sample ID	PFDA	PFHxA	d5NEFOS
		(70-130)	(70-130)	(70-130)
410-199620-1	SG1-LTB01-241205	96	101	102
410-199620-2	SG1-FTB01-241205	93	101	98
410-199620-3	GAC INFLUENT	105 cn	109 cn	93 cn
410-199620-3 - DL	GAC INFLUENT	119 cn	121 cn	112 cn
410-199620-4	GAC MIDFLUENT	97	102	96
410-199620-5	GAC EFFLUENT	98	99	99
LCS 410-584000/2-A	Lab Control Sample	96	98	97
LCSD 410-584000/3-A	Lab Control Sample Dup	98	102	95
MB 410-584000/1-A	Method Blank	98	101	99
Surrogate Legend				
PFDA = 13C2 PFDA				
PFHxA = 13C2 PFHxA				
d5NEFOS = d5-NEtFOSAA				

Isotope Dilution Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)						
Lab Sample ID	Client Sample ID	M262FTS (26-200)	M282FTS (27-200)	PFBA (10-168)	PFPeA (15-189)	C8PFOS (44-153)	PFOSA (11-149)	C3PFHS (39-164)
410-199620-1	SG1-LTB01-241205	96	91	64	79	93	85	89
410-199620-2	SG1-FTB01-241205	92	88	73	77	90	89	87
410-199620-3	GAC INFLUENT	105	94	59	102	95	86	102
410-199620-4	GAC MIDFLUENT	91	81	76	81	89	85	88
410-199620-5	GAC EFFLUENT	90	90	69	82	88	91	88
LCS 410-583949/2-A	Lab Control Sample	95	92	85	84	92	88	92
LCSD 410-583949/3-A	Lab Control Sample Dup	87	81	71	77	87	80	83
MB 410-583949/1-A	Method Blank	95	96	80	81	94	88	91

Surrogate Legend

M262FTS = M2-6:2 FTS

M282FTS = M2-8:2 FTS

PFBA = 13C4 PFBA

PFPeA = 13C5 PFPeA

C8PFOS = 13C8 PFOS

PFOSA = 13C8 FOSA

C3PFHS = 13C3 PFHxS

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified

Lab Sample ID: MB 410-583949/1-A

Matrix: Water

Analysis Batch: 585703

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 583949

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
6:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
8:2 Fluorotelomer sulfonic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
Perfluorobutanoic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
Perfluorodecanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
Perfluoroheptanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
Perfluorooctanesulfonamide	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1
Perfluoropentanoic acid	2.0	U	2.0	ng/L		12/10/24 06:53	12/14/24 00:48	1

Isotope Dilution	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
M2-6:2 FTS	95		26 - 200	12/10/24 06:53	12/14/24 00:48	1
M2-8:2 FTS	96		27 - 200	12/10/24 06:53	12/14/24 00:48	1
13C4 PFBA	80		10 - 168	12/10/24 06:53	12/14/24 00:48	1
13C5 PFPeA	81		15 - 189	12/10/24 06:53	12/14/24 00:48	1
13C8 PFOS	94		44 - 153	12/10/24 06:53	12/14/24 00:48	1
13C8 FOSA	88		11 - 149	12/10/24 06:53	12/14/24 00:48	1
13C3 PFHxS	91		39 - 164	12/10/24 06:53	12/14/24 00:48	1

Lab Sample ID: LCS 410-583949/2-A

Matrix: Water

Analysis Batch: 585703

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 583949

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
6:2 Fluorotelomer sulfonic acid	24.4	21.7		ng/L		89	56 - 130
8:2 Fluorotelomer sulfonic acid	24.6	25.8		ng/L		105	55 - 130
Perfluorobutanoic acid	25.6	26.6		ng/L		104	56 - 130
Perfluorodecanesulfonic acid	24.7	23.8		ng/L		96	53 - 130
Perfluoroheptanesulfonic acid	24.4	24.7		ng/L		101	55 - 130
Perfluorooctanesulfonamide	25.6	24.2		ng/L		94	64 - 133
Perfluoropentanoic acid	25.6	25.5		ng/L		100	56 - 130

Isotope Dilution	LCS %Recovery	LCS Qualifier	Limits
M2-6:2 FTS	95		26 - 200
M2-8:2 FTS	92		27 - 200
13C4 PFBA	85		10 - 168
13C5 PFPeA	84		15 - 189
13C8 PFOS	92		44 - 153
13C8 FOSA	88		11 - 149
13C3 PFHxS	92		39 - 164

Lab Sample ID: LCSD 410-583949/3-A

Matrix: Water

Analysis Batch: 585703

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 583949

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
6:2 Fluorotelomer sulfonic acid	24.4	23.1		ng/L		95	56 - 130	6	30
8:2 Fluorotelomer sulfonic acid	24.6	28.3		ng/L		115	55 - 130	9	30
Perfluorobutanoic acid	25.6	25.8		ng/L		101	56 - 130	3	30
Perfluorodecanesulfonic acid	24.7	25.1		ng/L		102	53 - 130	5	30
Perfluoroheptanesulfonic acid	24.4	25.8		ng/L		106	55 - 130	4	30

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method: 537 (Mod) - EPA 537 Version 1.1 modified (Continued)

Lab Sample ID: LCSD 410-583949/3-A

Matrix: Water

Analysis Batch: 585703

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 583949

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorooctanesulfonamide	25.6	24.9		ng/L		97	64 - 133	3	30
Perfluoropentanoic acid	25.6	26.1		ng/L		102	56 - 130	2	30

Isotope Dilution	LCSD %Recovery	LCSD Qualifier	Limits
M2-6:2 FTS	87		26 - 200
M2-8:2 FTS	81		27 - 200
13C4 PFBA	71		10 - 168
13C5 PFPeA	77		15 - 189
13C8 PFOS	87		44 - 153
13C8 FOSA	80		11 - 149
13C3 PFHxS	83		39 - 164

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018

Lab Sample ID: MB 410-584000/1-A

Matrix: Water

Analysis Batch: 584707

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 584000

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
NEtFOSAA	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
NMeFOSAA	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorobutanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorodecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorododecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluoroheptanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorohexanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorohexanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorononanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorooctanesulfonic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorooctanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorotetradecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluorotridecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1
Perfluoroundecanoic acid	2.0	U	2.0	ng/L		12/10/24 07:40	12/12/24 02:13	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2 PFDA	98		70 - 130	12/10/24 07:40	12/12/24 02:13	1
13C2 PFHxA	101		70 - 130	12/10/24 07:40	12/12/24 02:13	1
d5-NEtFOSAA	99		70 - 130	12/10/24 07:40	12/12/24 02:13	1

Lab Sample ID: LCS 410-584000/2-A

Matrix: Water

Analysis Batch: 584707

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 584000

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
NEtFOSAA	60.0	61.7		ng/L		103	70 - 130
NMeFOSAA	60.0	60.2		ng/L		100	70 - 130
Perfluorobutanesulfonic acid	53.1	54.3		ng/L		102	70 - 130
Perfluorodecanoic acid	60.0	60.6		ng/L		101	70 - 130
Perfluorododecanoic acid	60.0	59.7		ng/L		99	70 - 130

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method: EPA 537.1 - EPA 537.1, Ver 1.0 Nov 2018 (Continued)

Lab Sample ID: LCS 410-584000/2-A

Matrix: Water

Analysis Batch: 584707

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 584000

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec Limits
	Added	Result	Qualifier				
Perfluoroheptanoic acid	60.0	59.4		ng/L		99	70 - 130
Perfluorohexanesulfonic acid	54.7	55.8		ng/L		102	70 - 130
Perfluorohexanoic acid	60.0	61.8		ng/L		103	70 - 130
Perfluorononanoic acid	60.0	60.8		ng/L		101	70 - 130
Perfluorooctanesulfonic acid	55.5	55.2		ng/L		99	70 - 130
Perfluorooctanoic acid	60.0	62.5		ng/L		104	70 - 130
Perfluorotetradecanoic acid	60.0	58.0		ng/L		97	70 - 130
Perfluorotridecanoic acid	60.0	61.4		ng/L		102	70 - 130
Perfluoroundecanoic acid	60.0	61.1		ng/L		102	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
13C2 PFDA	96		70 - 130
13C2 PFHxA	98		70 - 130
d5-NEtFOSAA	97		70 - 130

Lab Sample ID: LCSD 410-584000/3-A

Matrix: Water

Analysis Batch: 584707

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 584000

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec Limits	RPD	Limit
	Added	Result	Qualifier						
NEtFOSAA	60.0	58.7		ng/L		98	70 - 130	5	30
NMeFOSAA	60.0	57.8		ng/L		96	70 - 130	4	30
Perfluorobutanesulfonic acid	53.1	54.8		ng/L		103	70 - 130	1	30
Perfluorodecanoic acid	60.0	60.0		ng/L		100	70 - 130	1	30
Perfluorododecanoic acid	60.0	60.6		ng/L		101	70 - 130	2	30
Perfluoroheptanoic acid	60.0	60.4		ng/L		101	70 - 130	2	30
Perfluorohexanesulfonic acid	54.7	54.8		ng/L		100	70 - 130	2	30
Perfluorohexanoic acid	60.0	62.5		ng/L		104	70 - 130	1	30
Perfluorononanoic acid	60.0	60.9		ng/L		101	70 - 130	0	30
Perfluorooctanesulfonic acid	55.5	54.7		ng/L		98	70 - 130	1	30
Perfluorooctanoic acid	60.0	63.6		ng/L		106	70 - 130	2	30
Perfluorotetradecanoic acid	60.0	58.0		ng/L		97	70 - 130	0	30
Perfluorotridecanoic acid	60.0	58.7		ng/L		98	70 - 130	4	30
Perfluoroundecanoic acid	60.0	59.9		ng/L		100	70 - 130	2	30

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
13C2 PFDA	98		70 - 130
13C2 PFHxA	102		70 - 130
d5-NEtFOSAA	95		70 - 130

QC Association Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

LCMS

Prep Batch: 583949

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-199620-1	SG1-LTB01-241205	Total/NA	Water	SPE	
410-199620-2	SG1-FTB01-241205	Total/NA	Water	SPE	
410-199620-3	GAC INFLUENT	Total/NA	Water	SPE	
410-199620-4	GAC MIDFLUENT	Total/NA	Water	SPE	
410-199620-5	GAC EFFLUENT	Total/NA	Water	SPE	
MB 410-583949/1-A	Method Blank	Total/NA	Water	SPE	
LCS 410-583949/2-A	Lab Control Sample	Total/NA	Water	SPE	
LCSD 410-583949/3-A	Lab Control Sample Dup	Total/NA	Water	SPE	

Prep Batch: 584000

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-199620-1	SG1-LTB01-241205	Total/NA	Water	537.1 DW Prep	
410-199620-2	SG1-FTB01-241205	Total/NA	Water	537.1 DW Prep	
410-199620-3 - DL	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-199620-3	GAC INFLUENT	Total/NA	Water	537.1 DW Prep	
410-199620-4	GAC MIDFLUENT	Total/NA	Water	537.1 DW Prep	
410-199620-5	GAC EFFLUENT	Total/NA	Water	537.1 DW Prep	
MB 410-584000/1-A	Method Blank	Total/NA	Water	537.1 DW Prep	
LCS 410-584000/2-A	Lab Control Sample	Total/NA	Water	537.1 DW Prep	
LCSD 410-584000/3-A	Lab Control Sample Dup	Total/NA	Water	537.1 DW Prep	

Analysis Batch: 584707

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-199620-1	SG1-LTB01-241205	Total/NA	Water	EPA 537.1	584000
410-199620-2	SG1-FTB01-241205	Total/NA	Water	EPA 537.1	584000
410-199620-3	GAC INFLUENT	Total/NA	Water	EPA 537.1	584000
410-199620-4	GAC MIDFLUENT	Total/NA	Water	EPA 537.1	584000
410-199620-5	GAC EFFLUENT	Total/NA	Water	EPA 537.1	584000
MB 410-584000/1-A	Method Blank	Total/NA	Water	EPA 537.1	584000
LCS 410-584000/2-A	Lab Control Sample	Total/NA	Water	EPA 537.1	584000
LCSD 410-584000/3-A	Lab Control Sample Dup	Total/NA	Water	EPA 537.1	584000

Analysis Batch: 585319

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-199620-3 - DL	GAC INFLUENT	Total/NA	Water	EPA 537.1	584000

Analysis Batch: 585703

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-199620-1	SG1-LTB01-241205	Total/NA	Water	537 (Mod)	583949
410-199620-2	SG1-FTB01-241205	Total/NA	Water	537 (Mod)	583949
410-199620-3	GAC INFLUENT	Total/NA	Water	537 (Mod)	583949
410-199620-4	GAC MIDFLUENT	Total/NA	Water	537 (Mod)	583949
410-199620-5	GAC EFFLUENT	Total/NA	Water	537 (Mod)	583949
MB 410-583949/1-A	Method Blank	Total/NA	Water	537 (Mod)	583949
LCS 410-583949/2-A	Lab Control Sample	Total/NA	Water	537 (Mod)	583949
LCSD 410-583949/3-A	Lab Control Sample Dup	Total/NA	Water	537 (Mod)	583949

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Client Sample ID: SG1-LTB01-241205

Lab Sample ID: 410-199620-1

Date Collected: 12/05/24 00:00

Matrix: Water

Date Received: 12/07/24 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			583949	RC3V	ELLE	12/10/24 06:53
Total/NA	Analysis	537 (Mod)		1	585703	R7RE	ELLE	12/14/24 04:52
Total/NA	Prep	537.1 DW Prep			584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1		1	584707	WR4P	ELLE	12/12/24 03:07

Client Sample ID: SG1-FTB01-241205

Lab Sample ID: 410-199620-2

Date Collected: 12/05/24 09:50

Matrix: Water

Date Received: 12/07/24 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			583949	RC3V	ELLE	12/10/24 06:53
Total/NA	Analysis	537 (Mod)		1	585703	R7RE	ELLE	12/14/24 05:05
Total/NA	Prep	537.1 DW Prep			584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1		1	584707	WR4P	ELLE	12/12/24 03:20

Client Sample ID: GAC INFLUENT

Lab Sample ID: 410-199620-3

Date Collected: 12/05/24 10:00

Matrix: Water

Date Received: 12/07/24 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			583949	RC3V	ELLE	12/10/24 06:53
Total/NA	Analysis	537 (Mod)		1	585703	R7RE	ELLE	12/14/24 05:19
Total/NA	Prep	537.1 DW Prep			584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1		1	584707	WR4P	ELLE	12/12/24 03:34
Total/NA	Prep	537.1 DW Prep	DL		584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1	DL	10	585319	WR4P	ELLE	12/13/24 00:52

Client Sample ID: GAC MIDFLUENT

Lab Sample ID: 410-199620-4

Date Collected: 12/05/24 10:12

Matrix: Water

Date Received: 12/07/24 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			583949	RC3V	ELLE	12/10/24 06:53
Total/NA	Analysis	537 (Mod)		1	585703	R7RE	ELLE	12/14/24 05:32
Total/NA	Prep	537.1 DW Prep			584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1		1	584707	WR4P	ELLE	12/12/24 03:47

Client Sample ID: GAC EFFLUENT

Lab Sample ID: 410-199620-5

Date Collected: 12/05/24 10:21

Matrix: Water

Date Received: 12/07/24 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	SPE			583949	RC3V	ELLE	12/10/24 06:53
Total/NA	Analysis	537 (Mod)		1	585703	R7RE	ELLE	12/14/24 05:46
Total/NA	Prep	537.1 DW Prep			584000	DX7G	ELLE	12/10/24 07:40
Total/NA	Analysis	EPA 537.1		1	584707	WR4P	ELLE	12/12/24 04:01

Eurofins Lancaster Laboratories Environment Testing, LLC

Lab Chronicle

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16

Accreditation/Certification Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
New York	NELAP	10670	04-01-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
537 (Mod)	SPE	Water	6:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	8:2 Fluorotelomer sulfonic acid
537 (Mod)	SPE	Water	Perfluorobutanoic acid
537 (Mod)	SPE	Water	Perfluorodecanesulfonic acid
537 (Mod)	SPE	Water	Perfluoroheptanesulfonic acid
537 (Mod)	SPE	Water	Perfluorooctanesulfonamide
537 (Mod)	SPE	Water	Perfluoropentanoic acid

Method Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Method	Method Description	Protocol	Laboratory
537 (Mod)	EPA 537 Version 1.1 modified	EPA	ELLE
EPA 537.1	EPA 537.1, Ver 1.0 Nov 2018	EPA	ELLE
537.1 DW Prep	Extraction of Perfluorinated Alkyl Acids	EPA	ELLE
SPE	PFAS by SPE	Lab SOP	ELLE

Protocol References:

EPA = US Environmental Protection Agency
Lab SOP = Laboratory Standard Operating Procedure

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Sample Summary

Client: CT Male Associates DPC
Project/Site: Hoosick Falls WTP

Job ID: 410-199620-1
SDG: HOO

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-199620-1	SG1-LTB01-241205	Water	12/05/24 00:00	12/07/24 09:40
410-199620-2	SG1-FTB01-241205	Water	12/05/24 09:50	12/07/24 09:40
410-199620-3	GAC INFLUENT	Water	12/05/24 10:00	12/07/24 09:40
410-199620-4	GAC MIDFLUENT	Water	12/05/24 10:12	12/07/24 09:40
410-199620-5	GAC EFFLUENT	Water	12/05/24 10:21	12/07/24 09:40



410-199620 Chain of Custody

Chain of Custody Record

Client Contact: Jonathan Dippert		Sampler: Lucas Swart		Lab PM: Kelly, Gallagher		Carrier Tracking No(s):		COC No:	
Company: CT Male Associates DPC		Phone: 518-786-7400		E-Mail: kelly.gallagher@et.eurolinsus.com		State of Origin: NY		Page: Page 1 of 1	
Address: 50 Century Hill Dr		City: Latham		State, Zip: NY, 12110		Phone: 518-786-7400		Email: j.dippert@ctmale.com	
Project Name: Hoosick Falls WTP		Site: SGPP - McCaffrey		Project #: 41000511		SSOW#:		Analysis Requested	
Due Date Requested:		TAT Requested (days): Standard		Compliance Project: ☐ Yes ☐ No		PO #: 14.4756		WO #:	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=Water, S=solid, O=soil/sediment, ST=Sludge, A=Air)	
SG1-LTB01-241205		12/5/24		—		G		W	
SG1-FTB01-241205		12/5/24		0950		G		W	
GAC INFLUENT		12/5/24		1000		G		W	
GAC MIDFLUENT		12/5/24		1012		G		W	
GAC EFFLUENT		12/5/24		1021		G		W	
Preservation Code:		N		Y					
Field Filtered Sample (Yes or No)		Perform MS/MS (Yes or No)		PFC_IDA (MOD) 7 PFAS Compounds		S37_DW - 14 PFAS Drinking Water List		Total Number of Containers	
Special Instructions/Note:									
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological									
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months									
Deliverable Requested: I, II, III, IV, Other (specify) EQUIS-1, ASP-B									
Special Instructions/QC Requirements:									
Empty Kit Relinquished by: _____ Date: _____ Time: _____ Method of Shipment: _____									
Relinquished by: Lucas Swart		Date/Time: 12/5/24 12:40		Company: CTM		Received by: _____		Date/Time: _____ Company: _____	
Relinquished by: _____		Date/Time: _____		Company: _____		Received by: _____		Date/Time: _____ Company: _____	
Relinquished by: _____		Date/Time: _____		Company: _____		Received by: _____		Date/Time: 12/7/24 09:40 Company: MVB	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: 12.3 - 20.4					

Login Sample Receipt Checklist

Client: CT Male Associates DPC

Job Number: 410-199620-1

SDG Number: HOO

Login Number: 199620

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

List Number: 1

Creator: Ballard, Megan

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature acceptable,where thermal pres is required(</=6C, not frozen).	True	
Cooler Temperature is recorded.	True	
WV:Container Temp acceptable,where thermal pres is required (</=6C, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	True	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	N/A	

Sample Preservation Checks (performed by the laboratory)

Question	Answer	Comment
Did the sample containers checked meet expected preservation conditions?	False	Refer to Job Narrative for details.