

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600023444-SR-1**

Report Date: **05/24/2016**

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by lrw03 on 06/08/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by:

Submitter's Reference Number: 02

Grab/Collection Date: 05/19/2016 08:50
Date received: 05/19/2016 14:15

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC MIDWAY
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600023444-01

Sample Type: Finished Water

Received Temperature (°C): 13.9

Lab Tracking Id: 02

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS)

Start Date: 5/20/2016 Analysis Date: 5/20/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600023443-SR-1

Report Date: 05/24/2016

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by lrw03 on 06/08/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by:

Submitter's Reference Number: 01

Grab/Collection Date: 05/19/2016 08:47

Date received: 05/19/2016 14:15

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFFLUENT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600023443-01

Sample Type: Finished Water

Received Temperature (°C): 14.9

Lab Tracking Id: 01

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS)

Start Date: 5/20/2016 Analysis Date: 5/20/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600023446-SR-1**

Report Date: **05/24/2016**

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by lrw03 on 06/08/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by: TIM VICKERSON

Submitter's Reference Number: 04

Grab/Collection Date: 05/19/2016 09:42
Date received: 05/19/2016 14:15

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: DPW RESTROOM CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600023446-01

Sample Type: Finished Water

Received Temperature (°C): **14.4**

Lab Tracking Id: 04

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS)

Start Date: 5/20/2016 Analysis Date: 5/20/2016

Perfluorooctanoic acid (PFOA): **<2 ng/L**

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600023447-SR-1**

Page 1 of 1

Report Date: **05/24/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 06/08/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by:

Submitter's Reference Number: 05

Grab/Collection Date: **05/19/2016 09:55**

Date received: **05/19/2016 14:15**

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: VILLAGE HALL MEN'S CWT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600023447-01

Sample Type: Finished Water

Received Temperature (°C): **14.7**

Lab Tracking Id: 05

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS)

Start Date: 5/20/2016 Analysis Date: 5/20/2016

Perfluorooctanoic acid (PFOA): **<2 ng/L**

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600023445-SR-1**

Page 1 of 1

Report Date: **05/24/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 06/08/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: TIM VICKERSON
Collected by:

Submitter's Reference Number: 03

Grab/Collection Date: **05/19/2016 08:50**

Date received: **05/19/2016 14:15**

OUTBREAK #: HFPFOA

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC INFLUENT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600023445-01

Sample Type: Finished Water

Received Temperature (°C): **14.2**

Lab Tracking Id: 03

Perfluoroalkyl Substances (PFASs) in Drinking Water by Ultra Performance Liquid Chromatography (UPLC) Tandem Mass Spectrometry (MS/MS)

Start Date: 5/20/2016 Analysis Date: 5/20/2016

Perfluorooctanoic acid (PFOA): **447 ng/L**

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.