

Sample Results

Client: New York State Department of Health
Project/Site: DOH - PFOA #442046

TestAmerica Job ID: 480-95857-1

Client Sample ID: TEMP GAC EFF

Lab Sample ID: 480-95857-4

Date Collected: 03/01/16 08:00

Matrix: Water

Date Received: 03/02/16 10:00

Method: WS-LC-0025-Perfluorinated Hydrocarbons done by TestAmerica Sacramento

| Analyte | Result | Qualifier | RL | MDL | Unit | Prepared | Analyzed | Dil Fac |
|--------------------------------------|-----------|-----------|--------|------|------|----------------|----------------|---------|
| Perfluoroheptanoic acid (PFHpA) | ND | | 1.9 | 0.75 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Perfluorooctanoic acid (PFOA) | ND | | 1.9 | 0.70 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Perfluorononanoic acid (PFNA) | ND | | 1.9 | 0.61 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | ND | | 1.9 | 0.86 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | | 1.9 | 0.81 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | ND | | 1.9 | 1.2 | ng/L | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| Isotope Dilution | %Recovery | Qualifier | Limit | | | Prepared | Analyzed | Dil Fac |
| 13C2 PFHxA | 77 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| 13C4 PFOA | 64 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| 13C5 PFNA | 43 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| 18O2 PFHxS | 107 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| 13C4 PFOS | 113 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |
| 13C4-PFHpA | 74 | | 25-150 | | | 03/08/16 11:06 | 03/09/16 13:23 | 1 |

%R: Percent Recovery

Dil Fac: Dilution Factor

MDL: Method Detection Limit

ND: Not detected at the reporting limit (or MDL or EDL if shown)

RL: Reporting Limit or Requested Limit (Radiochemistry)

ng/L: nanogram per liter

Sample Results

Client: New York State Department of Health
 Project/Site: DOH - PFOA #442046

TestAmerica Job ID: 480-96150-1

Client Sample ID: WTP GAC MID

Lab Sample ID: 480-96150-10

Date Collected: 03/07/16 14:55

Matrix: Water

Date Received: 03/08/16 10:00

Method: WS-LC-0025-Perfluorinated Hydrocarbons done by TestAmerica Sacramento

| <u>Analyte</u> | <u>Result</u> | <u>Qualifier</u> | <u>RL</u> | <u>MDL</u> | <u>Unit</u> | <u>Prepared</u> | <u>Analyzed</u> | <u>Dil Fac</u> |
|--------------------------------------|------------------|------------------|--------------|------------|-------------|-----------------|-----------------|----------------|
| Perfluoroheptanoic acid (PFHpA) | ND | | 1.9 | 0.76 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| Perfluorooctanoic acid (PFOA) | ND | | 1.9 | 0.71 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| Perfluorononanoic acid (PFNA) | ND | | 1.9 | 0.62 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | ND | | 1.9 | 0.87 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | | 1.9 | 0.83 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | ND | | 1.9 | 1.2 | ng/L | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| <u>Isotope Dilution</u> | <u>%Recovery</u> | <u>Qualifier</u> | <u>Limit</u> | | | <u>Prepared</u> | <u>Analyzed</u> | <u>Dil Fac</u> |
| 13C2 PFHxA | 80 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| 13C4 PFOA | 60 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| 13C5 PFNA | 42 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| 18O2 PFHxS | 93 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| 13C4 PFOS | 85 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |
| 13C4-PFHpA | 73 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:19 | 1 |

%R: Percent Recovery

Dil Fac: Dilution Factor

MDL: Method Detection Limit

ND: Not detected at the reporting limit (or MDL or EDL if shown)

RL: Reporting Limit or Requested Limit (Radiochemistry)

ng/L: nanogram per liter

Sample Results

Client: New York State Department of Health
Project/Site: DOH - PFOA #442046

TestAmerica Job ID: 480-96150-11

Client Sample ID: WTP GAC EFFLUENT

Date Collected: 03/07/16 14:50

Date Received: 03/08/16 10:00

Lab Sample ID: 480-96150-11

Matrix: Water

Method: WS-LC-0025-Perfluorinated Hydrocarbons done by TestAmerica Sacramento

| <u>Analyte</u> | <u>Result</u> | <u>Qualifier</u> | <u>RL</u> | <u>MDL</u> | <u>Unit</u> | <u>Prepared</u> | <u>Analyzed</u> | <u>Dil Fac</u> |
|--------------------------------------|------------------|------------------|--------------|------------|-------------|-----------------|-----------------|----------------|
| Perfluoroheptanoic acid (PFHpA) | ND | | 1.9 | 0.76 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| Perfluorooctanoic acid (PFOA) | ND | | 1.9 | 0.71 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| Perfluorononanoic acid (PFNA) | ND | | 1.9 | 0.62 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | ND | | 1.9 | 0.87 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | | 1.9 | 0.83 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | ND | | 1.9 | 1.2 | ng/L | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| <u>Isotope Dilution</u> | <u>%Recovery</u> | <u>Qualifier</u> | <u>Limit</u> | | | <u>Prepared</u> | <u>Analyzed</u> | <u>Dil Fac</u> |
| 13C2 PFHxA | 72 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| 13C4 PFOA | 58 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| 13C5 PFNA | 47 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| 18O2 PFHxS | 90 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| 13C4 PFOS | 75 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |
| 13C4-PFHpA | 68 | | 25-150 | | | 03/11/16 14:02 | 03/14/16 00:40 | 1 |

%R: Percent Recovery

Dil Fac: Dilution Factor

MDL: Method Detection Limit

ND: Not detected at the reporting limit (or MDL or EDL if shown)

RL: Reporting Limit or Requested Limit (Radiochemistry)

ng/L: nanogram per liter

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600011094-SR-2**

Page 1 of 1

****Replaces information in report No: EHS1600011094-SR-1**

Report Date: **03/11/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 03/17/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: LLOYD WILSON
Collected by:

Grab/Collection Date: 03/09/2016 14:25

Date received: 03/09/2016 20:20

Location/Project/Facility Name: BETWEEN FILTER
Chlorinated: No

SUPPLEMENTAL / FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600011094-01

Sample Type: Partly Processed Water

Received Temperature (°C): **22.2**

Lab Tracking Id: BETWEEN FILTER

Laboratory Special Analysis

Start Date: 03/09/16 21:00 Analysis Date: 3/10/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

NOTES:

****new****

[1] Sample transported at ambient temperature and refrigerated upon receipt.

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600011095-SR-2

Page 1 of 1

****Replaces information in report No: EHS1600011095-SR-1**

Report Date: 03/11/2016

Report retrieved via NYSDOH Health Commerce System by lrw03 on 03/17/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: LLOYD WILSON
Collected by:

Grab/Collection Date: 03/09/2016 14:22

Date received: 03/09/2016 20:20

Location/Project/Facility Name: AFTER CARBON FILTERS
Chlorinated: Yes

SUPPLEMENTAL / FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600011095-01

Sample Type: Finished Water

Received Temperature (°C): 22.1

Lab Tracking Id: AFTER CARBON FILTER

Laboratory Special Analysis

Start Date: 03/09/16 21:00 Analysis Date: 3/10/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

NOTES:

****new****

[1] Sample transported at ambient temperature and refrigerated upon receipt.

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600011793-SR-2**

Page 1 of 1

****Replaces information in report No: EHS1600011793-SR-1**

Report Date: **03/23/2016**

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: HFB

Grab/Collection Date: 03/11/2016 09:59

Date received: 03/11/2016 16:36

Additional Info: PUMP RUNNING

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: GAC EFFLUENT
Chlorinated: Yes

REVISED / FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600011793-01

Sample Type: Finished Water

Received Temperature (°C): **14.0**

Lab Tracking Id: 2- GAC EFF

Laboratory Special Analysis

Start Date: 3/12/2016 Analysis Date: 3/12/2016

****new****

Perfluorooctanoic acid (PFOA): <2 ng/L

****** Previously reported on 03/18/2016 as: Perfluorooctanoic acid (PFOA): <2 ng/L**

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600012191-SR-1

Report Date: 03/18/2016

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by: L. WILSON

Submitter's Reference Number: HF02

Grab/Collection Date: 03/14/2016 13:28
Date received: 03/15/2016 08:30

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFFLUENT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600012191-01

Sample Type: Finished Water

Received Temperature (°C):

5.1

Lab Tracking Id: 2- TEMP GAC EFF

Laboratory Special Analysis

Start Date: 03/15/16 09:00 Analysis Date: 03/15/16 12:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600012551-SR-1

Report Date: 03/18/2016

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by:

Submitter's Reference Number: HFAI

Grab/Collection Date: 03/15/2016 13:57
Date received: 03/15/2016 15:45

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFFLUENT

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600012551-01

Sample Type: Finished Water

Received Temperature (°C): 10.4

Lab Tracking Id: TEMP GAC EFF

Laboratory Special Analysis

Start Date: 3/16/2016 Analysis Date: 3/16/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health
Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600013501-SR-1**

Page 1 of 1

Report Date: **03/23/2016**

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: LLOYD WILSON
Collected by: J. HELMESET

Submitter's Reference Number: HF3

Grab/Collection Date: 03/18/2016 14:40

Date received: 03/20/2016 11:30

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: TEMP GAC EFF

Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600013501-01

Sample Type: Finished Water

Received Temperature (°C): **3.4**

Lab Tracking Id: TEMP GAC EFF

Laboratory Special Analysis

Start Date: 03/21/16 10:00 Analysis Date: 03/21/16 14:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600013533-SR-1**

Report Date: **03/23/2016**

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: L. WILSON
Collected by: T. VICKERSON

Submitter's Reference Number: HF19

Grab/Collection Date: 03/19/2016 12:20
Date received: 03/20/2016 11:30

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFF
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600013533-01

Sample Type: Finished Water

Received Temperature (°C): 3.4

Lab Tracking Id: TEMP GAC EFF

Laboratory Special Analysis

Start Date: 03/20/16 16:00 Analysis Date: 03/20/16 18:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600013543-SR-1

Report Date: 03/23/2016

Page 1 of 1

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: L. WILSON
Collected by: BILL GILDAY

Submitter's Reference Number: HF24

Grab/Collection Date: 03/20/2016 12:07
Date received: 03/20/2016 14:45

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: GAC EFFLUENT SAMPLE TAP
HOOSICK FALLS NY
Chlorinated: Yes
Field Free Chlorine Residual (mg/L): 0.05

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600013543-01

Sample Type: Finished Water

Received Temperature (°C): 10.8

Lab Tracking Id: GAC EFF

Laboratory Special Analysis

Start Date: 03/20/16 16:00 Analysis Date: 03/20/16 18:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600013908-SR-1

Page 1 of 1

Report Date: 03/29/2016

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: L. WILSON
Collected by: T. VICKERSON

Submitter's Reference Number: HFD

Grab/Collection Date: 03/22/2016 07:25

Date received: 03/22/2016 09:40

Additional Info: PUMP

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC LEAD
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600013908-01

Sample Type: Finished Water

Received Temperature (°C): 11.3

Lab Tracking Id: TEMP GAC LEAD

Laboratory Special Analysis

Start Date: 03/22/16 11:00 Analysis Date: 03/22/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600013907-SR-1**

Page 1 of 1

Report Date: **03/29/2016**

Report retrieved via NYSDOH Health Commerce System by lrw03 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: L. WILSON
Collected by: T. VICKERSON

Submitter's Reference Number: HFC

Grab/Collection Date: 03/22/2016 07:20
Date received: 03/22/2016 09:40

Additional Info: PUMP RUNNING

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS

Sampling Location Details: TEMP GAC EFF

Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry

NYS ELAP ID: 10763

Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan

CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600013907-01

Sample Type: Finished Water

Received Temperature (°C): **10.8**

Lab Tracking Id: TEMP GAC EFF

Laboratory Special Analysis

Start Date: 03/22/16 11:00 Analysis Date: 03/22/16 13:00

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: EHS1600014446-SR-1

Page 1 of 1

Report Date: 03/29/2016

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: HF09

Grab/Collection Date: 03/23/2016 16:03

Date received: 03/23/2016 21:30

Additional Info: PUMP RUNNING

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC LEAD FILTER 1
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600014446-01

Sample Type: Finished Water

Received Temperature (°C): 9.7

Lab Tracking Id: TEMP GAC LEAD

Laboratory Special Analysis

Start Date: 03/23/16 22:00 Analysis Date: 3/24/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

New York State Department of Health

Wadsworth Center

PO Box 509, Albany, New York 12201-0509

Report No: **EHS1600014445-SR-1**

Page 1 of 1

Report Date: **03/29/2016**

Report retrieved via NYSDOH Health Commerce System by msk02 on 03/29/2016

REQUESTED BY: DIRECTOR-WCENVIRO

DIRECTOR'S OFFICE
DIVISION OF ENVIRONMENTAL HEALTH SCIENCES
WADSWORTH CENTER
PO BOX 509
EMPIRE STATE PLAZA
ALBANY NY 12201-0509

Wadsworth Center - Environmental Labs

County: RENSSELAER
City (or) Town: HOOSICK FALLS
Submitted by: T. VICKERSON
Collected by: T. VICKERSON

Submitter's Reference Number: HF08

Grab/Collection Date: 03/23/2016 16:13

Date received: 03/23/2016 21:30

Additional Info: PUMP RUNNING

Location/Project/Facility Name: NY4100041, HOOSICK FALLS (V) PWS - HOOSICK FALLS
Sampling Location Details: TEMP GAC EFFLUENT
Chlorinated: Yes

FINAL LABORATORY REPORT

Laboratory of Organic Analytical Chemistry
NYS ELAP ID: 10763
Wadsworth Center, Empire State Plaza

LAB DIRECTOR: Dr. K. Kannan
CONTACT: Dr. David Spink 518-486-2530

Sample Id: EHS1600014445-01

Sample Type: Finished Water

Received Temperature (°C): **8.7**

Lab Tracking Id: TEMP GAC EFF

Laboratory Special Analysis

Start Date: 03/23/16 22:00 Analysis Date: 3/24/2016

Perfluorooctanoic acid (PFOA): <2 ng/L

END OF REPORT

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.